

US011692730B2

(12) **United States Patent**
Flaherty et al.

(10) **Patent No.:** **US 11,692,730 B2**
(45) **Date of Patent:** **Jul. 4, 2023**

(54) **HVAC ZONING DEVICES, SYSTEMS, AND METHODS**

(71) Applicant: **Ademco Inc.**, Golden Valley, MN (US)

(72) Inventors: **James Flaherty**, St. Louis Park, MN (US); **Nathaniel D. Kraft**, Minnetonka, MN (US); **Preston Gilmer**, Delano, MN (US)

(73) Assignee: **Ademco Inc.**, Golden Valley, MN (US)

(*) Notice: Subject to any disclaimer, the term of this patent is extended or adjusted under 35 U.S.C. 154(b) by 242 days.

(21) Appl. No.: **17/170,394**

(22) Filed: **Feb. 8, 2021**

(65) **Prior Publication Data**

US 2021/0165926 A1 Jun. 3, 2021

Related U.S. Application Data

(63) Continuation of application No. 14/745,073, filed on Jun. 19, 2015, now Pat. No. 10,915,669.
(Continued)

(51) **Int. Cl.**

F24F 11/64 (2018.01)

F24F 11/62 (2018.01)

(Continued)

(52) **U.S. Cl.**

CPC **F24F 11/64** (2018.01); **F24D 19/1084** (2013.01); **F24F 11/30** (2018.01);

(Continued)

(58) **Field of Classification Search**

CPC **F24D 19/1084**; **F24F 11/64**; **F24F 11/74**; **F24F 2140/40**

See application file for complete search history.

(56) **References Cited**

U.S. PATENT DOCUMENTS

1,949,101 A 2/1934 Greenewalt

1,950,101 A 3/1934 Dixon

(Continued)

FOREIGN PATENT DOCUMENTS

AU 667634 B2 3/1996

AU 688762 B2 3/1998

(Continued)

OTHER PUBLICATIONS

Venmar, Venmar Air Exchangers, Oct. 22, 2012.

(Continued)


Primary Examiner — Schyler S Sanks

(74) *Attorney, Agent, or Firm* — Greenberg Traurig, LLP; Ryan D. Sharp; David J. Dykeman

(57) **ABSTRACT**

A heating, ventilation, and air conditioning (HVAC) system may be zoned into one or more zone. The HVAC system may include HVAC components, sensors, and one or more register vents that may include vent dampers (e.g., electronically controllable vent dampers or manually operated vent dampers). Opening and closing of the vent dampers may facilitate creating zones or sub-zones in the HVAC system configuration. An HVAC control system may receive a request for conditioned air in one or more of the zones, determine a damper setting for at least one of the vent dampers, communicate the determined damper setting to a vent damper or user interface, determine which HVAC components should be active, if any, and/or provide controls signals to activate or keep active the HVAC components that are determined to be active.

20 Claims, 6 Drawing Sheets



Related U.S. Application Data					
(60)	Provisional application No. 62/015,168, filed on Jun. 20, 2014.			5,983,890 A	11/1999 Martin et al.
				6,021,252 A	2/2000 Faris et al.
				6,079,626 A	6/2000 Hartman et al.
				6,102,792 A	8/2000 Nystrom
				6,213,404 B1	4/2001 Dushane et al.
				6,216,956 B1	4/2001 Ehlers et al.
				6,219,590 B1	4/2001 Bemaden, III et al.
				6,237,854 B1	5/2001 Avni
				6,295,823 B1	10/2001 Odom et al.
				6,296,193 B1	10/2001 West et al.
				6,349,883 B1	2/2002 Simmons et al.
				6,364,211 B1	4/2002 Selah
				6,574,581 B1	6/2003 Bohrer et al.
				6,575,233 B1	6/2003 Krumnow
				6,659,359 B2	12/2003 Kwak
				6,676,508 B1	1/2004 Graham
				6,688,384 B2	2/2004 Eoga
				6,692,349 B1	2/2004 Brinkerhoff et al.
				6,741,915 B2	5/2004 Poth
				6,879,881 B1	4/2005 Attridge, Jr.
				6,983,889 B2	1/2006 Alles
				6,986,469 B2	1/2006 Gauthier et al.
				6,997,390 B2	2/2006 Alles
				7,003,378 B2	2/2006 Poth
				7,055,759 B2	6/2006 Wacker et al.
				7,063,140 B1	6/2006 Woo
				7,130,720 B2	10/2006 Fisher
				7,147,168 B1	12/2006 Bagwell et al.
				7,156,316 B2	1/2007 Kates
				7,163,156 B2	1/2007 Kates
				7,168,627 B2	1/2007 Kates
				7,222,494 B2	5/2007 Peterson et al.
				7,222,800 B2	5/2007 Wruck
				7,261,241 B2	8/2007 Eoga
				7,392,661 B2	7/2008 Alles
				7,455,236 B2	11/2008 Kates
				7,455,237 B2	11/2008 Kates
				7,548,833 B2	6/2009 Ahmed
				7,551,983 B2	6/2009 Attridge, Jr.
				7,601,054 B2	10/2009 Bagwell et al.
				7,606,635 B2	10/2009 Fisher
				7,693,591 B2	4/2010 Høglund et al.
				7,726,582 B2	6/2010 Federspiel
				7,788,936 B2	9/2010 Peterson et al.
				7,809,472 B1	10/2010 Silva et al.
				7,832,465 B2	11/2010 Zou et al.
				7,880,421 B2	2/2011 Karwath
				7,904,209 B2	3/2011 Podgomy et al.
				7,957,839 B2	6/2011 Takach et al.
				7,983,796 B2	7/2011 Kassel
				8,010,237 B2	8/2011 Cheung et al.
				8,014,902 B2	9/2011 Kates
				8,020,777 B2	9/2011 Kates
				8,024,073 B2	9/2011 Imes et al.
				8,033,479 B2	10/2011 Kates
				8,038,075 B1	10/2011 Walsh
				8,078,325 B2	12/2011 Poth
				8,086,352 B1	12/2011 Elliott
				8,090,477 B1	1/2012 Steinberg
				8,108,076 B2	1/2012 Imes et al.
				8,112,181 B2	2/2012 Remsburg
				8,116,913 B2	2/2012 Mirpourian et al.
				8,143,828 B2	3/2012 Becerra et al.
				8,147,302 B2	4/2012 Desrochers et al.
				8,167,216 B2	5/2012 Schultz et al.
				8,185,244 B2	5/2012 Wolfson
				8,190,301 B2	5/2012 Voysey
				8,209,059 B2	6/2012 Stockton
				8,219,252 B2	7/2012 Nanami
				8,224,490 B2	7/2012 Knyazev
				8,224,491 B2	7/2012 Koster et al.
				8,229,596 B2	7/2012 Majias
				8,369,995 B2	2/2013 Nanami
				8,387,892 B2	3/2013 Koster et al.
				8,397,527 B2	3/2013 Miller
				8,417,386 B2	4/2013 Douglas et al.
				8,418,128 B2	4/2013 Pouchak et al.
				8,495,888 B2	7/2013 Seem
				8,515,584 B2	8/2013 Miller et al.
(51)	Int. Cl.				
	<i>F24F 11/58</i>	(2018.01)			
	<i>F24F 11/46</i>	(2018.01)			
	<i>F24F 11/70</i>	(2018.01)			
	<i>G06F 30/13</i>	(2020.01)			
	<i>F24F 11/74</i>	(2018.01)			
	<i>F24F 11/54</i>	(2018.01)			
	<i>F24D 19/10</i>	(2006.01)			
	<i>F24F 11/30</i>	(2018.01)			
	<i>F24F 110/00</i>	(2018.01)			
	<i>F24F 110/10</i>	(2018.01)			
	<i>F24F 110/20</i>	(2018.01)			
	<i>F24F 110/50</i>	(2018.01)			
	<i>F24F 130/20</i>	(2018.01)			
	<i>F24F 140/40</i>	(2018.01)			
	<i>F24F 120/20</i>	(2018.01)			
	<i>F24F 11/65</i>	(2018.01)			
	<i>F24F 11/56</i>	(2018.01)			
	<i>F24F 11/52</i>	(2018.01)			
	<i>F24F 120/00</i>	(2018.01)			
(52)	U.S. Cl.				
	CPC	<i>F24F 11/46</i> (2018.01); <i>F24F 11/54</i> (2018.01); <i>F24F 11/58</i> (2018.01); <i>F24F 11/62</i> (2018.01); <i>F24F 11/70</i> (2018.01); <i>F24F 11/74</i> (2018.01); <i>G06F 30/13</i> (2020.01); <i>F24F 11/52</i> (2018.01); <i>F24F 11/56</i> (2018.01); <i>F24F 11/65</i> (2018.01); <i>F24F 2110/00</i> (2018.01); <i>F24F 2110/10</i> (2018.01); <i>F24F 2110/20</i> (2018.01); <i>F24F 2110/50</i> (2018.01); <i>F24F 2120/00</i> (2018.01); <i>F24F 2120/20</i> (2018.01); <i>F24F 2130/20</i> (2018.01); <i>F24F 2140/40</i> (2018.01)			
(56)	References Cited				
	U.S. PATENT DOCUMENTS				
	1,951,101 A	3/1934	Miller		
	RE22,870 E *	4/1947	Peple, Jr.	<i>F24F 11/75</i>	236/49.5
	5,024,265 A	6/1991	Buchholz et al.		
	5,303,767 A	4/1994	Riley		
	5,305,953 A	4/1994	Rayburn et al.		
	5,318,099 A	6/1994	Zivalich et al.		
	5,337,955 A	8/1994	Burd		
	5,344,068 A	9/1994	Haessig et al.		
	5,348,078 A	9/1994	Dushane et al.		
	5,394,324 A	2/1995	Clearwater et al.		
	5,415,346 A	5/1995	Bishop		
	5,447,037 A	9/1995	Bishop et al.		
	5,449,112 A	9/1995	Heitman et al.		
	5,449,319 A	9/1995	Dushane et al.		
	5,495,887 A	3/1996	Kalhnelson et al.		
	5,520,328 A	5/1996	Bojak, Jr.		
	5,651,264 A	7/1997	Lo et al.		
	5,704,545 A	1/1998	Sweitzer, Jr.		
	5,751,572 A	5/1998	Maciulewicz et al.		
	5,768,121 A	6/1998	Federspiel et al.		
	5,810,245 A	9/1998	Heitman et al.		
	5,829,674 A *	11/1998	Vanostrand	<i>F24F 11/74</i>	165/208
	5,833,134 A	11/1998	Ho et al.		
	5,839,654 A	11/1998	Weber et al.		
	5,860,473 A	1/1999	Seiden		
	5,882,254 A	3/1999	Jacob et al.		
	5,927,398 A	7/1999	Maciulewicz et al.		
	5,944,098 A	8/1999	Jackson et al.		
	5,962,989 A	10/1999	Baker		

(56)

References Cited

U.S. PATENT DOCUMENTS

8,543,244 B2 9/2013 Keeling et al.
 8,550,370 B2 10/2013 Barrett et al.
 8,555,662 B2 10/2013 Peterson et al.
 8,579,205 B2 11/2013 Augusto et al.
 8,651,391 B2 2/2014 Patch
 8,660,708 B2 2/2014 Narayanamurthy et al.
 8,661,165 B2 2/2014 Grohman et al.
 8,695,888 B2 4/2014 Kates
 8,702,482 B2 4/2014 Helt et al.
 8,963,726 B2 2/2015 Kates
 8,963,727 B2 2/2015 Kates
 8,963,728 B2 2/2015 Kates
 8,981,950 B1 3/2015 Kates
 9,007,225 B2 4/2015 Kates
 9,019,110 B2 4/2015 Kates
 9,182,140 B2 11/2015 Kates
 9,183,733 B2 11/2015 Kates
 9,194,599 B2 11/2015 Kates
 9,194,600 B2 11/2015 Kates
 9,222,692 B2 12/2015 Kates
 10,151,502 B2 12/2018 Flaherty et al.
 2001/0048030 A1 12/2001 Sharood et al.
 2002/0123896 A1 9/2002 Diez et al.
 2003/0014161 A1 1/2003 Orthlieb et al.
 2003/0200050 A1 10/2003 Sharma
 2004/0118933 A1 6/2004 Readio et al.
 2004/0166797 A1 8/2004 Thrasher et al.
 2004/0194484 A1 10/2004 Zou et al.
 2005/0090915 A1 4/2005 Geiwitz
 2005/0127196 A1 6/2005 Gottlieb
 2005/0155365 A1 7/2005 Shah et al.
 2005/0156049 A1 7/2005 Van Ostrand et al.
 2005/0156050 A1 7/2005 Shah et al.
 2005/0159848 A1 7/2005 Shah et al.
 2005/0173548 A1 8/2005 Kramer
 2005/0194456 A1 9/2005 Tessier et al.
 2005/0270151 A1 12/2005 Winick
 2005/0278071 A1 12/2005 Durham
 2005/0279845 A1 12/2005 Bagwell et al.
 2005/0284622 A1 12/2005 Nichols
 2006/0036350 A1 2/2006 Bohrer et al.
 2006/0071087 A1 4/2006 Kates
 2006/0099904 A1 5/2006 Belt et al.
 2006/0185275 A1 8/2006 Yatt
 2006/0185373 A1 8/2006 Butler et al.
 2007/0012052 A1 1/2007 Butler et al.
 2007/0023533 A1 2/2007 Liu
 2007/0045431 A1 3/2007 Chapman et al.
 2007/0051822 A1 3/2007 Wolfson
 2007/0119958 A1 5/2007 Kates
 2007/0228183 A1 10/2007 Kennedy et al.
 2008/0011864 A1 1/2008 Tessier et al.
 2008/0033599 A1 2/2008 Aminpour et al.
 2008/0054083 A1 3/2008 Evans
 2008/0099568 A1 5/2008 Nicodem et al.
 2008/0133033 A1 6/2008 Wolff et al.
 2008/0161976 A1 7/2008 Stanimirovic
 2008/0179053 A1 7/2008 Kates
 2008/0208654 A1 8/2008 Nahikian et al.
 2008/0251590 A1 10/2008 Ameson
 2009/0008463 A1 1/2009 Holland et al.
 2009/0065595 A1 3/2009 Kates
 2009/0140064 A1 6/2009 Schultz et al.
 2009/0166442 A1 7/2009 Stark
 2009/0204262 A1 8/2009 Nishimura
 2009/0266904 A1 10/2009 Cohen
 2009/0271154 A1 10/2009 Coad et al.
 2010/0012737 A1 1/2010 Kates
 2010/0045470 A1 2/2010 Araiza et al.
 2010/0082162 A1 4/2010 Mundy et al.
 2010/0084482 A1 4/2010 Kennedy et al.
 2010/0106334 A1 4/2010 Grohman et al.
 2010/0163633 A1 7/2010 Barrett et al.
 2010/0168924 A1 7/2010 Tessier et al.
 2010/0204834 A1 8/2010 Comerford et al.

2010/0307733 A1 12/2010 Karamanos et al.
 2011/0015802 A1 1/2011 Imes
 2011/0031322 A1 2/2011 Zou et al.
 2011/0034120 A1 2/2011 Jaiyeola
 2011/0040550 A1 2/2011 Graber et al.
 2011/0046798 A1 2/2011 Imes et al.
 2011/0046799 A1 2/2011 Imes et al.
 2011/0054701 A1 3/2011 Wang et al.
 2011/0062246 A1 3/2011 Khalafi
 2011/0112875 A1 5/2011 Johnson et al.
 2011/0127340 A1 6/2011 Aiken
 2011/0172828 A1 7/2011 Schmidt et al.
 2011/0198404 A1 8/2011 Dropmann
 2011/0202185 A1 8/2011 Imes et al.
 2011/0214060 A1 9/2011 Imes et al.
 2011/0246898 A1 10/2011 Imes et al.
 2011/0257795 A1 10/2011 Narayanamurthy et al.
 2011/0270446 A1 11/2011 Scharf et al.
 2011/0276183 A1 11/2011 Liu
 2012/0041603 A1 2/2012 Wilmsen et al.
 2012/0048952 A1 3/2012 Slingsby et al.
 2012/0072030 A1 3/2012 Elliott
 2012/0072031 A1 3/2012 Elliott
 2012/0072033 A1 3/2012 Imes et al.
 2012/0101637 A1 4/2012 Imes et al.
 2012/0101648 A1 4/2012 Federspiel et al.
 2012/0116728 A1 5/2012 Shear et al.
 2012/0161682 A1 6/2012 Becerra et al.
 2012/0217315 A1 8/2012 Witbeck et al.
 2012/0221718 A1 8/2012 Imes et al.
 2012/0228393 A1 9/2012 Storm et al.
 2012/0239202 A1 9/2012 Voysey
 2012/0239208 A1 9/2012 Federspiel et al.
 2012/0253524 A1 10/2012 Norrell et al.
 2012/0298763 A1 11/2012 Young
 2012/0310416 A1 12/2012 Tepper et al.
 2013/0054033 A1 2/2013 Casilli
 2013/0057937 A1 3/2013 Berman et al.
 2013/0069541 A1 3/2013 Feri et al.
 2013/0081799 A1 4/2013 Loblich et al.
 2013/0085613 A1 4/2013 Bester et al.
 2013/0138249 A1 5/2013 Cho et al.
 2013/0138250 A1 5/2013 Mowery et al.
 2013/0182905 A1 7/2013 Myers et al.
 2013/0245838 A1 9/2013 Zywicki et al.
 2013/0268129 A1 10/2013 Fadell et al.
 2013/0297078 A1 11/2013 Kolavennu
 2013/0310986 A1 11/2013 Gust et al.
 2013/0310987 A1 11/2013 Sobek et al.
 2013/0334326 A1 12/2013 Shan
 2013/0338837 A1 12/2013 Hublou et al.
 2013/0338839 A1 12/2013 Rogers et al.
 2014/0000861 A1 1/2014 Barrett et al.
 2014/0031993 A1 1/2014 Matsuoka
 2014/0034284 A1 2/2014 Butler et al.
 2014/0041846 A1 2/2014 Leen et al.
 2014/0052300 A1 2/2014 Matsuoka et al.
 2014/0067130 A1 3/2014 Pillai et al.
 2014/0101082 A1 4/2014 Matsuoka et al.
 2014/0319232 A1 10/2014 Gourlay et al.
 2015/0057810 A1 2/2015 Smith et al.
 2015/0276250 A1* 10/2015 Lintern C09K 8/528
 454/251
 2015/0369503 A1 12/2015 Flaherty et al.
 2015/0369504 A1 12/2015 Flaherty et al.
 2015/0369507 A1 12/2015 Flaherty et al.
 2018/0023826 A1 1/2018 Tucker et al.
 2018/0032969 A1 2/2018 Gillette et al.

FOREIGN PATENT DOCUMENTS

AU 2005294681 A1 4/2006
 AU 2009231670 A1 10/2009
 AU 2008229674 A1 4/2010
 AU 2010276364 A2 8/2012
 AU 2010284375 B2 10/2014
 CA 1326705 C 2/1994
 CA 2005497 C 5/1994
 CA 2077199 C 8/1997

(56)

References Cited

FOREIGN PATENT DOCUMENTS

CA	2025279	C	5/1998
CA	2582232	A1	4/2006
CA	2599471	A1	2/2009
CA	2748724	A1	7/2010
CA	2699034	A1	8/2010
CA	2698794	A1	9/2010
CA	2677047	A1	11/2010
CA	2668812	A1	12/2010
CA	2768799	A1	1/2011
CA	2771280	A1	2/2011
CA	2771638	A1	2/2011
CA	2818696	A1	5/2012
CA	2769288	A1	9/2012
CA	2798477	A1	6/2013
CA	2719932	C	10/2013
CA	2698845	C	11/2013
CN	101048624	A	10/2007
CN	101145276	A	3/2008
CN	101194129	B	10/2010
CN	101999252	A	3/2011
CN	202328615	U	7/2012
CN	102882752	A	1/2013
CN	103229116	A	7/2013
DE	10126475	A1	3/2003
DK	201200174	A	9/2013
EP	0660051	A2	6/1995
EP	0632234	B1	3/1998
EP	0721089	B1	8/2000
EP	0892330	B1	10/2002
EP	0889291	B1	4/2004
EP	2014994	A2	1/2009
EP	2690372	A2	1/2014
GB	2452345	A	3/2009
GB	2477860	A	8/2011
JP	2002245102	A	8/2002
JP	2003287240	A	10/2003
JP	2006300484	A	11/2006
JP	2012078049	A	4/2012
WO	WO 2006041599	A2	4/2006
WO	WO 2006099125	A2	9/2006
WO	WO 2007027632	A2	3/2007
WO	WO 2008016500	A2	2/2008
WO	WO 2008030791	A2	3/2008
WO	WO 2009073034	A1	6/2009
WO	WO 2009124217	A1	10/2009
WO	WO 2010078459	A1	7/2010
WO	WO 2011011404	A1	1/2011
WO	WO 2011022379	A1	2/2011
WO	WO 2011062942	A1	5/2011
WO	WO 2011100736	A2	8/2011
WO	WO 2011120091	A1	10/2011
WO	WO 2012068591	A2	5/2012
WO	WO 2012092622	A2	7/2012
WO	WO 2012092625	A2	7/2012
WO	WO 2012092627	A1	7/2012
WO	WO 2012112415	A1	8/2012
WO	WO 2013043863	A1	3/2013
WO	WO 2013173433	A1	11/2013
WO	WO 2013179080	A1	12/2013
WO	WO 2014033189	A1	3/2014
WO	WO 2014051632	A1	4/2014

OTHER PUBLICATIONS

Tekmar, Tekmar Control Systems, Discover the Benefits of Hydronic Heating or Cooling, Nov. 26, 2012.

Arzel Zoning Technology, Inc., “Zonocity: Zoning for Small Duct High Velocity Applications (SDHV),” <http://www.arelzoning.com/products/zonocity>, 2 pages, printed Jun. 17, 2014.

Brown, “Multizone Register Controlled Residential Heating: Optimized for Energy Use and Comfort,” Center for the Built Environment, UC Berkeley, 62 pages, 2007. (Applicant points out, in accordance with MPEP 609.04(a), that the year of publication,

2007, is sufficiently earlier than the effective U.S. filing date, so that the particular month of publication is not in issue.)

Carrier, “A 6-in-1 Device: Intelligent Residential Control Introduced by Carrier,” <http://www.transicold.carrier.com/Carrier+Corporate+Sites/Corporate/Side+Bar+Ulinks/Giobai+News/ci.A+6-in-1+Device%3A+Intelligent+Residential+Control...>, 3 pages, May 29, 2014.

Carrier, Carrier Comfort System (VVTIII), 6 pages, Aug. 1996.

Carrier, “VVT Comfort System, 33 CS,” 6 pages, Oct. 1997.

Dounis Et al., “Advanced Control Systems Engineering for Energy and Comfort Management in a Building Environment—A Review,” Renewable and Sustainable Energy Reviews, vol. 13, pp. 1246-1261, 2009. (Applicant points out, in accordance with MPEP 609.04(a), that the year of publication, 2009, is sufficiently earlier than the effective U.S. filing date, so that the particular month of publication is not in issue.)

Home Climate Control, “Technical FAQ: HVAC: Excess Static Pressure Relief,” <http://www.homeclimatecontrol.com/faq/technical-hvac-excess-static-pressure-relief>, 5 pages, printed, May 19, 2014.

Honeywell, “WiFi Color Touchscreen Programmable Thermostat, RTH9590 WiFi With Voice Control, Quick Start Guide,” 20 pages, Feb. 2014.

<http://www.linkedin.com/groups/JCI-new-ASSET-tool-is-4767612>. S.198141514, “JCI New ASSET Tool is a Game Changer,” 2 pages, printed Jun. 17, 2014.

<http://www.statscrop.com/www/theactivent.com>, “Theactivent.com, The Activent, Web Analysis,” 5 pages, printed May 16, 2014. <https://developer.apple.com/homekit/>, “HomeKit, Apple Developer,” 2 pages, printed Jan. 21, 2016.

<https://web.archive.org/web/20040609142352/http://diy-zoning.sourceforge.net/Advanced/dampers.html>, “DIY Zoning: Dampers,” 2 pages, Jun. 9, 2004.

<https://web.archive.org/web/20040613050818/http://www.smarthomeusa.com/Shop/Climate/rcs/RCS-Zone-Controllers/item/ZC6R-232/>, “RCS HVAC 6 Zone Controller (RS-232 Version)-ZC6R-232-SmartHomeUSA.com,” 2 pages, Jun. 13, 2004.

<https://web.archive.org/web/20040624153603/http://diy-zoning.sourceforge.net/Development/contract.html>, “DIY Zoning: Design Contract,” 2 pages, Jun. 24, 2004.

<https://web.archive.org/web/20081204093741/http://www.smarthome.com/3096H146/In-Wall-Motorized-Registers/p.aspx>, “In-Wall Motorized Registers—Smarthome,” 2 pages, Dec. 4, 2008.

<https://web.archive.org/web/20130724192824/http://diy-zoning.sourceforge.net/Advanced/dampers.html>, “DIY Zoning: Dampers,” 4 pages, Jul. 24, 2013.

https://www.webarchive.org/web/20080602013118/http://www.commercial.carrier.com/commercial/hvac/product_description/1,3059,CL11_DIV12_ETI434_PRD189.00..., “Carrier: 33ZCFANTRM VAV Fan Terminal Zone Controller,” pages, Jun. 2008.

Jackson Systems, “Comfort System VAV Diffuser,” 2 pages, downloaded May 19, 2014.

Johnson Controls, “Facility Explorer ASSET Application/System Selection & Estimating Tool,” 2 pages, 2012. (Applicant points out, in accordance with MPEP 609.04(a), that the year of publication, 2012, is sufficiently earlier than the effective U.S. filing date, so that the particular month of publication is not in issue.)

Nova, “Activent Electronic Room Temperature Regulator, User Manual and Installation Guide,” 7 pages, downloaded May 16, 2014.

Redfern et al., “Design Architecture for Multi-Zone HVAC Control Systems From Existing Single-Zone Systems Using Wireless Sensor Networks,” Proceedings of SPIE, vol. 6414, 2007. (Applicant points out, in accordance with MPEP 609.04(a), that the year of publication, 2007, is sufficiently earlier than the effective U.S. filing date, so that the particular month of publication is not in issue.) Residential Control Systems Inc., “RCS Model ZC6R, 6 Zone HVAC Control Unit,” 2 pages, Feb. 2002.

Siemens, “HIT: Online Version Supports Energy Efficiency Standard,” Press Release, 2 pages, Feb. 20, 2009.

Telkonet, “EcoWave Remote Thermostat Package,” 2 pages, Jan. 2013.

(56)

References Cited

OTHER PUBLICATIONS

The Activent, "Individual Room Zoning Systems," <http://www.theactivent.com/>, 2 pages, printed May 16, 2014.

Trane, "Light Commercial Integrated Comfort System," 6 pages, 2004. (Applicant points out, in accordance with MPEP 609.04(a), that the year of publication, 2004, is sufficiently earlier than the effective U.S. filing date, so that the particular month of publication is not in issue.)

Trane, "Light Commercial Integrated Comfort System," 6 pages, 2001. (Applicant points out, in accordance with MPEP 609.04(a), that the year of publication, 2004, is sufficiently earlier than the effective U.S. filing date, so that the particular month of publication is not in issue.)

Trane, "VariTrac Central Control Panel, Intallation Manual, VAV-SVN03A-EN," 72 pages, Jun. 2002.

Trane, "VariTrane Products," VAV-PRC008-EN, 308 pages, Mar. 2003.

Trane, "VariTrane Products," VAV-PRC008-EN, 321 pages, May 2006.

Vadim Tkachenko, "DIY Zoning: Design Contract," 3 pages, 2000. (Applicant points out, in accordance with MPEP 609.04(a), that the year of publication, 2000, is sufficiently earlier than the effective U.S. filing date, so that the particular month of publication is not in issue.)

Prosecution History from U.S. Appl. No. 14/745,073, dated May 24, 2017 through Sep. 3, 2020, 107 pp.

* cited by examiner




FIG. 1




FIG. 2




FIG. 3




FIG. 4




FIG. 5




FIG. 6

HVAC ZONING DEVICES, SYSTEMS, AND METHODS

This application is a continuation of U.S. patent application Ser. No. 14/745,073, filed Jun. 19, 2015, entitled, "HVAC Zoning Devices, Systems, and Methods," which claims the benefit of U.S. Provisional Application Ser. No. 62/015,168, filed Jun. 20, 2014, entitled, "HVAC Zoning Devices, Systems, and Methods," the entire content of both applications being incorporated herein by reference.

TECHNICAL FIELD

The present disclosure relates generally to HVAC systems, and more particularly, to HVAC systems that can be configured to accommodate zone control.

BACKGROUND

Heating, ventilation, and/or air conditioning (HVAC) systems are often used to control the comfort level within a building or other structure. Such HVAC systems typically include an HVAC controller that controls various HVAC components of the HVAC system in order to affect and/or control one or more environmental conditions within the building. Such HVAC controllers typically have a user interface for allowing a user to interact and the HVAC controller. The user interface is often integral with the HVAC controller housing, but in some instances, can be remote from the HVAC controller, such as when using a user interface of a smart phone, tablet computer, personal computer, laptop etc.

SUMMARY

The present disclosure relates generally to HVAC systems, and more particularly, to HVAC systems that can be configured to accommodate zone control.

In one example, an HVAC system may include one or more HVAC components for providing conditioned air to one or more HVAC ducts of the building and a plurality of electronically controllable register vent dampers for controlling delivery of the conditioned air from the one or more HVAC ducts into the building. In some cases, each of the plurality of electronically controllable register vents may be configured to sense one or more local conditions in the building and issue one or more requests for conditioned air. The HVAC system may be controlled by an HVAC control system and may include, among other elements, a communications block and a controller operatively coupled to the communications block. The communications block may receive one or more requests for conditioned air issued by one or more of the plurality of register vents and thus, the controller may receive the one or more requests for conditioned air. In response to the requests, the controller may determine a damper setting for at least one of the plurality of electronically controllable register vent dampers and communicate the determined damper setting for the at least one of the plurality of electronically controllable register vent dampers via the communications block. In some instances, the controller may determine which HVAC components should be active, if any, to accommodate the requests and provide one or more control signals to activate or keep active the one or more HVAC components that are to be active.

In some cases, the HVAC control system configured to control the HVAC system may include two or more sensors

to sense environmental parameters at two or more different locations in the building. At least one of the two or more sensors may sense an environmental parameter other than temperature (e.g., humidity, CO₂ concentration, VOC concentration, or other parameter other than temperature). In such cases, the controller may control one or more HVAC components and electronically controllable register vent dampers based, at least in part, on the sensed environmental parameter other than temperature.

In some instances, the HVAC system may include one or more HVAC components for providing conditioned air to one or more HVAC ducts of a building and a plurality of electronically controllable register vent dampers for controlling delivery of conditioned air from the one or more HVAC ducts into each of two or more zones of the building. Each of the zones of the building may have at least one sensor for sensing a sensed condition in the corresponding zone.

The preceding summary is provided to facilitate an understanding of some of the innovative features unique to the present disclosure and is not intended to be a full description. A full appreciation of the disclosure can be gained by taking the entire specification, claims, drawings, and abstract as a whole.

BRIEF DESCRIPTION OF THE DRAWINGS

The disclosure may be more completely understood in consideration of the following description of various illustrative embodiments in connection with the accompanying drawings, in which:

FIG. 1 is a schematic view of an illustrative HVAC system servicing a building or structure;

FIG. 2 is a schematic block diagram of an illustrative register vent;

FIG. 3 is a schematic block diagram of another illustrative register vent;

FIG. 4 is a schematic block diagram of an illustrative connection between a remote system and a building automation system;

FIG. 5 is a schematic diagram of an illustrative local device sensing system; and

FIG. 6 is a schematic diagram of illustrative components of various levels of HVAC system configurations.

While the disclosure is amenable to various modifications and alternative forms, specifics thereof have been shown by way of example in the drawings and will be described in detail. It should be understood, however, that the intention is not to limit aspects of the disclosure to the particular illustrative embodiments described. On the contrary, the intention is to cover all modifications, equivalents, and alternatives falling within the spirit and scope of the disclosure.

DESCRIPTION

The following description should be read with reference to the drawings wherein like reference numerals indicate like elements throughout the several views. The description and drawings show several embodiments which are meant to be illustrative in nature.

FIG. 1 is a schematic view of a building 2 having an illustrative building automation system 4 with a building automation sub-system 12. While FIG. 1 shows a typical forced air type HVAC system as an illustrative building automation sub-system 12, other building automation sub-systems 12 (e.g., devices or systems at least partially local to a space conditioned by the HVAC system or other

building automation sub-systems **12**) are contemplated including, but not limited to, security systems, lighting control systems, water heater systems (e.g., boiler systems), refrigerators, clothes washers, clothes dryers, ovens, garage doors, radiant heating systems, electric heating systems, cooling systems, heat pump systems, register vent systems, any other suitable sub-system **12** of building automation systems **4**, and/or portions thereof, as desired.

In some instances, the building automation system **4** may include and/or be in communication with a remote system **36** (see FIG. **4** and description in greater detail below). The remote system **36** may be a system that is remote from one or more components of a building automation controller **18** and/or physically remote from the building **2**. In some cases, the remote system **36** may, at least partially, reside on one or more servers located in the cloud and remote from the building **2**, where the one or more servers may include a memory and a processor configured to execute instructions stored on the memory and/or stored on other memory.

An HVAC system of building **2** may be controlled by an HVAC control system implemented in one or more of a wall mounted thermostat, an equipment interface module, a remote system **36** (e.g., cloud server) or other device. The HVAC control system may include a communications block and a controller operatively coupled to the communications block. The communications block may receive information from the HVAC system and the controller may receive the information and in response, use the information in analyses, to make determinations, to provide recommendations to a user interface, and/or to provide control signals to the HVAC system. In some cases, the HVAC control system (e.g., a building control system) may include a building automation controller **18**, a remote system **36**, and/or other controller.

The illustrative HVAC system of FIG. **1** may include one or more HVAC components **6**, a system of ductwork and air vents including a supply air duct **10** and a return air duct **14**, and one or more building automation controllers **18** (e.g., central HVAC controllers, thermostats, etc.), where an HVAC component **6** may provide conditioned air to one or more HVAC supply air ducts **10**. The one or more HVAC components **6** may include, but are not limited to, a fan, a portable electric fan, a ceiling fan, a furnace (e.g., a forced air furnace or other furnace), a boiler, a hot water heater, a heat pump, an electric heat pump, a geothermal heat pump, an electric heater, a fireplace, a floor heater, an air conditioning unit, a window air conditioning unit, a wall air conditioning unit, hydronic heating and/or cooling unit/components, a humidifier, a dehumidifier, an air exchanger, an air cleaner, a register vent, a damper, a register vent damper to change air flow characteristics of an associated register (e.g., one or more manually operated register vent dampers and/or one or more electronically controlled register vent dampers), a valve, a ventilation unit for bringing in outside air into the building and exhausting inside air from the building, UV lamps, air purification systems, air cleaning systems, and/or the like.

In some instances, one or more of the HVAC components **6** (e.g., hydronic heating, electric heating strips, etc.) may be utilized in a stage with one or more other HVAC components **6** (e.g., in a forced air heating system, etc.). In an example, electric heating strips may be a stage in a heat pump system, where the electric heating strips may supplement the heat pump system when outdoor temperatures become too cold.

In some cases, combinations of HVAC components **6** may be used to provide quicker response times in reaching a set point than if only a single HVAC component **6** or system is used. Faster response times may be particularly noticeable

when manually changing the setpoint temperature or when recovering from a programmed setback temperature, particularly when using a hydronic or other heating system that has a slower response time.

It is contemplated that a building automation controller(s) **18** may be configured to activate, deactivate, and/or otherwise modulate the building automation sub-system(s) **12** (e.g., the HVAC system) or components of the building automation sub-system(s) **12** (e.g., HVAC components **6**) of the building automation system **4** in a controlled manner (e.g., to control the comfort level in one or more spaces of the structure or building **2** and/or otherwise operate electronic features of the building **2** and provide suggestions for manual configuration of manually adjustable devices). The building automation controller(s) **18** may be configured to control the devices of the building automation system **4** or building automation sub-systems **12** via a wired or wireless communication link **20**.

In some cases, the building automation controller(s) **18** may be or may include a thermostat, such as, for example, a wall mountable thermostat or intelligent power switch (e.g., for controlling appliances not equipped with communications capabilities and other appliances), but this is not required in all instances. An example thermostat may include (e.g. within the thermostat housing), or have access to, a temperature sensor for sensing an ambient temperature at, near, or spaced from the thermostat and/or other sensors for sensing other comfort level conditioning parameters (e.g., humidity, occupancy, sound, light, particle levels, etc.). In some instances, the building automation controller(s) **18** may be or may include an equipment interface module (EIM), a zone controller, or multiple EIMs or zone controllers each monitoring and/or controlling the comfort level within a particular zone or space (e.g., a comfort level conditioned space) in the building **2** or other structure.

In the illustrative building automation system **4** shown in FIG. **1**, the HVAC component(s) **6** (e.g., components of or in communication with the building automation controller **18** or building automation sub-system **12**) may provide heated air (and/or cooled air) via the ductwork **10**, **14** throughout the building **2**. As illustrated, the HVAC component(s) **6** may be in fluid communication with every room and/or zone in the building **2** via the ductwork **10** and **14**, but this is not required. In operation, when a heat call or command signal is provided by the building automation controller(s) **18**, an HVAC component **6** (e.g. forced warm air from a furnace) may be activated to supply heated air to one or more rooms and/or zones within the building **2** via supply air ducts **10**. The heated air may be forced through the supply air duct **10** by a blower or fan **21**. In this example, the cooler air from each zone may be returned to the HVAC component **6** for heating via return air ducts **14**. Similarly, when a cool call or command signal is provided by the building automation controller(s) **18**, an HVAC component **6** (e.g. an air conditioning unit) may be activated to supply cooled air to one or more rooms and/or zones within the building **2** or other structure via supply air ducts **10**. The cooled air may be forced through the supply air duct **10** by the blower or fan **21**. In this example, the warmer air from each zone may be returned to the HVAC component **6** (e.g. air conditioning unit) for cooling via return air ducts **14**. In some cases, the wired or wireless communication link **20** of the building automation system **4** may include an internet gateway (e.g., a modem or other device facilitating a communication link) or other device that may allow one or more of the HVAC components **6**, as described herein, to communicate over a wide area network (WAN) such as, for

5

example, the Internet, and/or a device (e.g., wired or wireless communication link 20) that may allow one or more HVAC components 6 to communicate over any other network.

In many instances, one or more air filters 23 may be used to remove dust and other pollutants from the air inside the building 2. In the illustrative example shown in FIG. 1, the air filter(s) 23 are installed in the return air duct 14, and may filter the air prior to the air entering the HVAC component 6, but it is contemplated that any other suitable location for the air filter(s) 23 may be used. The presence of the air filter(s) 23 may not only improve the indoor air quality, but may also protect the HVAC components 6 from dust and other particulate matter that would otherwise be permitted to enter the HVAC component 6.

In some cases, the system of vents or ductwork 10 and/or 14 may include one or more dampers 24 to regulate the flow of air through the vent, but this is not required. The dampers 24 may be positioned along the ductwork 10 and/or 14 at any location. One or more active dampers 24 may be coupled (e.g., in a wired or wireless manner) to one or more HVAC controller(s) 18, EIMs, or zone controllers and may be coordinated with the operation of one or more HVAC components 6. The one or more HVAC controller(s) 18 may actuate active dampers 24 to an opened position, a closed position, and/or to a position between the opened position and closed position (e.g., a partially opened position) to modulate the flow of air from the one or more HVAC components 6 to an appropriate room and/or zone in the building 2 or other structure. The dampers 24 may be particularly useful in zoned HVAC systems, and may be used to control which zone(s) receive(s) conditioned air from the HVAC component(s) 6.

In some instances, register vents 26 may include one or more vent dampers 30 located at or adjacent a position which air or fluid exits the ductwork 10 and enters a conditioned space to control delivery of the conditioned air from the one or more supply air duct 10 into the building 2. The register vents 26 may include one or more manually operated register vents 26 with manually operated vent damper 30a (see FIG. 2) and/or one or more electronically controlled active register vents 26 with an electronically operated vent damper 30b (see FIG. 3). In some cases, the register vents 26 may be manually operated and electronically operated.

Illustratively, the register vents 26 may be utilized in any manner to facilitate comfort level conditioning in one or more spaces. In some instances, the register vents 26 may be utilized to form one or more zones in a comfort level conditioned space. For example, the register vents 26 may be utilized to create one or more zones in the conditioned space even though, to that point, the HVAC system was not a zoned system. Alternatively, or in addition, register vents 26 may be utilized to create one or more further zones or one or more sub-zones in an HVAC system that is already configured to be at least partially zoned.

As shown in FIG. 1, a building 2 may include a plurality of zones (e.g., zone 1, zone 2, and zone 3, or any other number of zones) with at least one sensor (e.g., a sensor at or of a building automation controller 18, a local sensor 34 (see below), or other sensor) in each zone. In some cases, each zone may include one or more electronically controllable register vent dampers 30b, such that the building automation controller 18 or other controller may be able to control the first zone differently from the second zone. Although the HVAC system in FIG. 1 for building 2 may be configured to include three zones, register vents 26 may be

6

included in the HVAC system to provide additional or alternate control over the flow of fluid through the ductwork of the HVAC system and conditioned spaces of the building 2. For example, when a room or zone has a plurality of registers (e.g., locations where fluid from ductwork 10 enters a room or zone), register vents 26 may be utilized to create subzones within a zone, such as zones 2A, 2B, 3A, and 3B, as shown separated by dotted lines in FIG. 1, by allowing a user and/or a controller (e.g., one or more building automation controller 18, one or more controller at the register vents 26, and/or other controller) to close and/or open vent dampers 30 at the register vents 26 (e.g., manually and/or electronically open and/or close vent dampers 30).

As mentioned, each zone of a building (e.g., building 2) may include at least one sensor. In some instances, a sensor (e.g., a local sensor 34) may be associated with each register vent 26, but this is not required. In some cases, a sensor may be associated with two or more register vents 26 (such as two register vents located in the same zone). Alternatively, or in addition, a sensor may be associated with the building automation controller 18 and/or may be a remote sensor in communication with the building automation controller 18. The sensors may be configured to sense one or more environmental parameters and may be in communication with a local controller or other mechanism for communicating the sensed parameter to a device configured to adjust and/or monitor comfort level conditioning settings of the building automation system 4 (e.g., the HVAC system of building 2).

Register vents 26 may include a vent 28 configured to receive fluid flow from a building automation sub-system 12 (e.g., fan 21, a furnace, an air conditioner, etc. of an HVAC system) and a manually operated vent damper 30a, as best shown in FIG. 2. The vent 28 may be in fluid communication with the ductwork 10 and the fluid traveling through the ductwork 10 may exit the ductwork through the vent 28. Where the ductwork 10 has a proximal end at an end adjacent a comfort level conditioned space and a distal end at an HVAC component 6 of a building automation sub-system 12, the manually operated vent damper 30a may be positioned proximal and/or distal of the vent 28. In some cases, the manually operated vent damper 30a may be mechanically coupled to the vent 28 to form a register vent 26 and/or the manually operated vent damper 30s.

In some instances, one or more register vents 26 of a plurality of register vents 26 of a conditioned space may be manually operated. Manually operated register vents 26 may be manually adjusted by a user by manually adjusting a mechanism to open and/or close a vent damper 30 with respect to an associated vent 28. Alternatively, or in addition, adding a manually operated vent damper 30a to a vent 28 may form a manually adjustable register vent 26.

In some cases, when a manually operable vent damper 30a is added to a vent 28, the vent damper 30 may be a magnetic sheet that is mechanically and/or electrically connected to a proximal side or distal side of the vent 28 and/or other vent damper 30 mechanism that may be mechanically connected to the vent 28. Manually operated register vents 26 refer to register vents 26 that include a manually operated vent damper 30a which may be manually adjusted by a user to control flow of fluid through an associated vent 28. In some instances, the manually operated register vents 26 may include a local controller and/or a local sensor for sensing environmental parameters, but this is not required.

In some instances, but not all, electronically controlled register vents 26 may include one or more of a vent 28, an electronically controlled vent damper 30b, an actuator 31, a

local controller 32, a communications port or block 33 having a wired or wireless interface for communicating with the HVAC control system and/or other register vents 26, and/or a local sensor 34. An electronically controlled register vent 26 may be a register vent 26 that is capable of

being selectively and/or automatically controlled by a controller (e.g. a local controller 32, a building automation controller 18, a remote system 36 and/or other controller). When a register vent 26 includes a local sensor 34 or other sensor, it may be considered a sensing device. The local controller 32 of the register vent may be in communication with a building automation controller 18 other controller of the HVAC control system via communications port or block 33 of the register vent 26 and/or other communications port or block (e.g., communications port or block 42, 44) having a wired or wireless interface and may be electronically controlled from the building automation controller 18 or other device or system in communication with the building automation controller 18. In instances when a plurality of electronically controlled register vents 26 are included in a building automation system 4, positions (e.g., an opened position, a closed position, or positions therebetween) of the electronically controlled vent dampers 30b with respect to the vents 28 of the electronically controlled register vents 26 may be controlled by the building automation controller 18 and/or any other controller including, but not limited to, the local controllers 32 at the register vent 26, and/or any device or system connected thereto.

Illustratively, the local sensor 34 of a register vent 26 associated with an electronically controlled register vent damper 30b may sense one or more local conditions in the building and the local controller 32 of the register vent 26 may communicate or issue one or more requests to the building automation controller 18 or other controller of the HVAC control system for conditioned air or other request of the HVAC system. In response to receiving the request, a controller of the HVAC control system may be configured to determine a setting (e.g., damper setting) for the electronically controlled register vent damper 30b and communicate the determined setting for the electronically controlled register vent damper 30b via the communications block of the HVAC control system to a user interface (e.g., user interface 46), to the local controller 32 of the register vent 26, and/or to one or more other device of the HVAC system or HVAC control system. The controller of the HVAC control system may determine which HVAC component(s) 6 should be active, if any, and provide one or more control signals to that HVAC component 6 to activate or keep active that HVAC component 6.

In some cases, the local controllers 32 may be in communication with one another to facilitate zone or sub-zone synchronization and/or optimization. In such instances, each local controller 32 may set a position of an associated vent damper 30 electronically in view of other set positions of other vent dampers 30 associated with other local controllers 32. In some instances, the local controllers 32 and/or other controllers in communication with the vent dampers 30 may consider the state of manually operated register vents 26, electronically operated register vents 26, vents 28 without vent dampers 30, and/or input from controllers (e.g., building automation controllers 18 or other controllers) of the building automation system 4 in addition to or other than the local controllers 32.

The local controllers 32 may be configured to have one-way or two-way communication with the building automation controller(s) 18 and/or a remote system 36 via communications port or block 33. In instances of one-way

communication with the building automation controller(s) 18 and/or remote system 36, the local controllers 32 may communicate positions of the vent dampers 30, sensed parameters at or about the register vent 26, and/or other information to the building automation controller(s) 18 and/or the remote system 36. Alternatively, the local controllers 32 having one-way communication with the building automation controller(s) 18 and/or remote system 36 may receive positioning commands for the vent dampers 30 and/or other information from the building automation controller(s) 18 and/or the remote system 36. In instances of two-way communication with the building automation controller(s) 18 and/or the remote system 36, the local controllers 32 may communicate positions of the vent dampers 30, sensed parameters at or about the register vents 26, and/or other information to the building automation controller(s) 18 and/or the remote system 36, and the local controllers 32 may receive positioning commands for the vent dampers 30 and/or other comfort level conditioning information/commands from the building automation controller(s) 18 and/or the remote system 36. In one example of communication between the register vents 26 and the building automation controller 18, the register vents 26 may be configured to call for conditioning (e.g., heating and/or cooling) of an associated space (e.g., a zone or sub-zone), call for fan 21 operation, call for humidification, call for dehumidification, call for air purification, and/or call for operation of one or more other pieces of equipment.

Control of the register vents 26 may be centralized at the building automation controller 18, at any other controller in the building 2 (e.g., including, but not limited to, one of the local controllers 32), and/or at the remote system 36. When register vents 26 are centrally controlled, the building automation controller 18, other controller, and/or the remote system 36 may be able to control comfort level conditioning in a calculated manner (e.g., keep at least 10%-70%, 20%-60%, 30%-50%, or other range of vent dampers 30 in an open position) due to the knowledge of how much fluid is passing to one or more locations and at what time that fluid is reaching one or more locations within a comfort level controlled space. Illustratively, a building automation controller 18 or other controller that centrally controls the register vents 26 may take into consideration vent damper 30 position settings of manually controlled register vents 26, along with position settings of electronically controlled register vents 26. Understanding the positioning of all of the vent dampers 30, if any, associated with vents 28 in a comfort level conditioned space allows the building automation controller 18 or other central controller to apply comfort level conditioning settings for the building automation system 4 in view of an amount of fluid calculated to be reaching one or more locations of a space or zone. Keeping some minimum percentage of the vent dampers open may also help prevent excessive load on the fan 21 of the HVAC system servicing the building.

As discussed, and in some instances, a register vent 26 may include one or more local sensors 34. The local sensors 34 may be configured to sense one or more parameters related to setting a comfort level in the conditioned space and store and/or communicate the sensed parameters via the local controller 32. In one example, the local sensors 34 may be configured to sense one or more of a temperature, physical occupancy/presence, changes in temperature, humidity levels, changes in humidity level, air quality levels or conditions (e.g., particle count, light, volatile organic compound (VOC) concentration or levels, CO₂ concentration or levels, etc.), changes in air quality levels or condi-

tions, sound through or around the register vents **26**, vibrations, voice patterns, pressure, flow, and/or any other suitable sensed parameters. In some instances, the local sensors **34** and the local controllers **32** may be separate components or may be part of a single component.

In response to sensing one or more parameters with a sensing device of the building automation system **4**, the local controllers **32**, the building automation controllers **18**, and/or the remote system **36** may take one or more actions to adjust a comfort level conditioning level within one or more particular spaces. In one example of using sensed parameters to adjust a comfort level within one or more particular spaces, a sensing device may provide a measurement of one or more sensed air quality conditions (e.g., particle count, light, volatile organic compound (VOC) concentration or levels, CO₂ concentration or levels, etc.) to a controller and the controller may determine settings for one or more air quality components (e.g., UV lamps, air purification systems, air cleaning systems, air exchangers, etc.) of the HVAC components **6** in the building automation system **4** based, at least in part, on the provided measurements of sensed air quality conditions.

As discussed in greater detail below, the HVAC control system may save or store values of sensed parameters in a remote system **36** (e.g., in a cloud server) and, in some cases, control one or more HVAC components **6** and/or register vent dampers **30** based, at least in part, on stored values of the sensed environmental parameters. Additionally, or alternatively, the HVAC control system may be configured to receive a request for data related to the sensed parameters and provide (e.g., to a user interface) a report for the data related to the sensed parameters based, at least in part, on the stored values of the sensed parameter.

The local controllers **32**, the building automation controllers **18**, and/or the remote system **36** may utilize outputs of a local sensor **34** as a primary sensed parameter for controlling comfort level conditioning of a space, as an averaged sensed parameter that is used in conjunction with other outputs of local sensors **34** and/or other sensors to control comfort level conditioning of a space, as a sensed zone parameter for controlling comfort level conditioning of a particular zoned or sub-zoned space, and/or as a sensed parameter for other comfort level conditioning. Such use of local sensors **34** at register vents **26** may facilitate dividing a comfort level conditioned space into zones (e.g., macro-zones) and/or sub-zones (e.g., micro-zones), identifying temperature gradients across a comfort level conditioned space and/or zones to optionally identify further zoning opportunities, improving an accuracy of a sensed parameter from a user comfort level perspective for a comfort level conditioned space by averaging a plurality of sensed parameters sensed by the local sensors **34**, and/or may facilitate providing other functions and/or benefits.

In some instances, the local sensors **34** or other sensors may sense when someone is present in a comfort level conditioned space and apply settings for the comfort level conditioned space associated with a “space occupied” profile or other profile. In other similar or different instances, the local sensors **34** may be configured to sense when a particular individual is present in a comfort level conditioned space and apply settings for the comfort level conditioned space associated with that particular individual’s profile saved in a memory of one or more of the local controller **32**, the building automation controller **18**, and the remote system **36**. The local sensors **34** may identify particular individuals in any manner, including but not limited to, sensing an individual’s biometrics, sensing an individual’s voice,

sensing vibrations caused by an individual advancing through a space, sensing an identification tag carried by the individual (e.g. RFID tag, cell phone, etc.), and/or other identifying techniques. Additionally, or alternatively, the local sensors **34** or other sensors may sense other parameters and/or apply one or more comfort level conditioning profiles as determined by a preset or predefined program of the HVAC system.

In some instances, a controller of or in communication with the HVAC system may be capable of identifying one or more local devices **56** (see FIG. **5**) in the building **2** via a communications block or port (e.g., wireless communications port or block **54** or other communications block or port). In one example, a building automation controller **18** may be configured to identify and/or detect one or more devices (e.g., local devices **56**) local to a space of which the building automation controller **18** at least partially controls the comfort level conditioning. In some cases, the building automation controller **18** or other controller may be able to control one or more of the local devices **56**. A local device **56** may be, but is not limited to, controllable or uncontrollable non-HVAC components such as an appliance, an oven, a stove, a window, a window treatment, a refrigerator, a cooler, a freezer, an iron, a grill, a room fan, an air freshener, a portable dehumidifier, a portable humidifier, and/or other indoor devices or goods that may have an effect on comfort level conditioning of a space. In some instances, a local device **56** may be an auxiliary environmental parameter control device including, but not limited to, a window air conditioning unit, a wall air conditioning unit, a portable electric heater, an electric fireplace, a portable electric fan, a ceiling fan, an electric floor heater, and so on.

A building automation controller **18** (e.g., a thermostat or other controller), as depicted in FIG. **5**, may include a processor **48** and memory **50**. In some cases, a device controller **52** (e.g., including memory and a processor—not shown) including or in communication with a wireless communications port or block **54** may be included in the building automation controller **18** as a sub-controller of the building automation controller **18** or other feature thereof. Additionally, or alternatively, the device controller **52** may be located exterior the building automation controller **18** and may be in communication with the building automation controller **18** via a wired or wireless connection. The device controller **52** of or in communication with the building automation controller **18** may be configured to automatically or upon request sense via a wired connection or through the wireless communication port or block **54** (e.g., over one or more wireless protocols, including, but not limited to, cellular communication, IEEE 802.11, ZigBee, REDLINK™, Bluetooth, WiFi, IrDA, dedicated short range communication (DSRC), EnOcean, and/or any other suitable common or proprietary wireless protocol, as desired) one or more local devices **56** and/or actions taken thereby.

The device controller **52** may be configured to automatically or upon request sense a local device **56**, sense an action taken thereby through detecting one or more changes in environmental parameters, and/or send a control signal to the local device **56**. In such instances, the device controller **52** may be in communication with the local sensors **34** or other sensors of the HVAC system to receive environment parameter data. Through analyses of changes in the received environmental parameter data, the device controller **52** may identify the presence of a local device **56** and/or an action taken thereby. In some cases, the device controller **52** may detect a presence of a local device **56** via a wired or wireless communication and the device controller **52** may identify an

11

action taken by a local device **56** via analysis of environmental parameter data. In one example, the device controller **52** may analyze data received from a local sensor **34** adjacent a stove and may determine when the data from the local sensor **34** is indicating a rise in temperature. From the identification of the rise in temperature, the device controller **52** may identify the stove has taken a heating action and indicate that action taken to the processor **48** of the building automation controller **18**. In response, the building automation controller **18** may set a vent damper **30** of a register vent **26** adjacent the space in which the stove is located to an opened position to cool the space and/or take other actions to compensate for the identified action taken by the stove.

When the device controller **52** detects that a local device **56** has taken an action or has been caused to make an action, the device controller **52** may provide a signal to the processor **48** of the building automation controller **18**. In response to receiving a signal from the device controller **52** indicating a local device is taking or has made an action, the building automation controller **18** may, via a user interface **46** (e.g., the user interface **46** may be, but is not limited to one or more of, a mobile phone, a personal digital assistant, a laptop computer, a desktop computer, a thermostat screen, a voice control system, and other interfaces), suggest an adjustment to, or may automatically adjust, an environmental parameter set point of one or more HVAC components **6** conditioning a particular space or particular zone. In one instance, the building automation controller **18** may be configured to adjust a position setting of a vent damper **30** of one or more register vents **26** adjacent the space in which the local device **56** is located in response to the device controller **52** detecting one or more of a local device **56** and an action taken or made by the detected local device **56**.

In some cases, the device controller **52** may be configured to detect one or more auxiliary environmental parameter control devices (e.g., a portable heater, a window air conditioner, or space conditioning device not directly controlled by the building automation controller **18**). In response to detection of one or more of the auxiliary environmental parameter control devices and communication of the detection to the processor **48** of the building automation controller **18**, the building automation controller **18** may be configured to adjust a position setting of a vent damper **30** of one or more register vents **26** and/or adjust one or more other settings. In some instances, the device controller **52** may receive a status signal from the auxiliary environmental parameter control device indicating a setting thereof (e.g., on/off, hi/low, level 1 or 2 or 3, etc.), and the building automation controller **18** may adjust a position of vent damper **30** of one or more register vents **26** and/or other settings to account for the setting of the auxiliary environmental parameter control device and maintain proper comfort level conditioning in a space. In some cases, the device controller **52** may change a setting of the auxiliary environmental parameter control device, such as turn on or off the auxiliary environmental parameter control device.

In some cases, the local sensors **34** and/or other sensors of the building automation system **4** that may be configured to sense one or more parameters of a comfort level conditioned space and may communicate the sensed parameters to the remote system **36** via one or more operably coupled local controllers **32** and/or the building automation controller **18** through the use of an operably coupled local communications port or block **44**, as best shown in FIG. 4. Illustratively, the remote system **36** and/or the building automation controller **18** may include a memory **38** and a processor **40**, where the memory **38** or other memory may store data

12

obtained from the sensors of the building automation system **4**, other data from users, and/or instructions executable by the processor **40** to analyze and/or configure the data obtained from the sensors of the building automation system **4** and/or configure other data obtained from a user. The memory **38** and/or other memory discussed herein may be non-transitory computer readable media. In one instance, the processor **40** may be configured to execute instructions stored in the memory **38** or other memory to perform thermodynamic analyses, model development, HVAC configuration development, and/or other analyses using the data and/or information received from the building automation system **4** and additionally or alternatively configure the data and/or results of the analyses for communication to a user interface **46** of or in communication with the building automation system **4**.

The user interface **46** may be configured to communicate with controllers (e.g., the remote system **36** (e.g., cloud server), the local controller **32**, the building automation controller **18**, and/or other controllers) of or in communication with the HVAC system to obtain and/or receive analyses from one or more of the controllers based on data received from the local sensors **34** and/or other data. The obtained and/or received analyses may be of data specific to one or more particular zones or sub-zones and/or to any portion of or an entirety of the space that is conditioned with the building automation system **4**. Illustratively, the controllers of the HVAC system of a building **2** may monitor the thermodynamics of different areas of the building **2**. Such monitoring may include tracking heat gain and/or loss of each zone independently of other zones, which may allow the controllers to send to the user interface **46** suggested position settings for vent dampers **30** that may impact a rate of heating or cooling of a particular conditioned space of a building **2**. The positioning of vent dampers **30** according to suggested position settings may facilitate establishing more even temperatures throughout a building because different spaces/zones/sub-zones throughout a building **2** may reach a set temperature at a more similar time, rather than at different times, which is often the case when all of the vent dampers **30** are set to the fully open position.

In addition, or as an alternative, to obtained and/or received analyses of data from local sensors **34**, the obtained and/or received analyses at a user interface **46** may take into account data for area conditioning parameters of a plurality of HVAC systems, sizes of the vents **28** of the register vents **26**, and/or sizes of the vent dampers **30** of the register vents **26**. In some cases, the plurality of HVAC systems may be located in a single building or in one or more buildings about or around a subject building **2** (e.g., buildings in a neighborhood, on a same city block, etc.). In one example, the remote system **36** may be configured to monitor homes (e.g., buildings **2**) in a community and track the impact of suggested changes to positions of vent dampers **30** and/or suggested changes to other HVAC components **6** on the operation of HVAC systems or thermodynamics in those homes. The remote system **36** may then compare the suggested changes of similar type, sized, geographically positioned, and/or geographically oriented homes to one another to determine successful changes. The successful changes may then be tracked over time and suggested to other users of the remote system **36** in response to environmental season changes, solar strength changes, humidity level changes, and/or other changes.

In some cases, analyses obtained and/or received by the user interface **46**, may include recommendations for configuring one or more HVAC components **6** of an HVAC

system. Illustratively, the recommendations may include one or more zoning recommendations, register vent **26** setting recommendations, temperature set point (or temperature program schedule) recommendations, etc., from the remote system **36**, the local controllers **32**, the building automation controllers **18**, and/or other controllers.

The one or more zoning recommendations may, as discussed in further detail below, be developed based at least partially on sensed conditioning parameters of an area to be comfort level conditioned and/or data for sensed conditioning parameters of areas to be comfort level conditioned by one or more other HVAC systems (e.g., HVAC systems in buildings other than a subject building **2**) received through a communications port or block (e.g., communications port or block **42** and/or communications port or block **44**). Zoning recommendations may include general instructions or suggestions on how to zone a building **2**, how to manually set zones, how to modify an existing zone to create sub-zones, when to modify an existing zone, how to set vent dampers **30** of register vents, and/or other instructions.

In one example of a building automation system **4** obtaining instructions, the remote system **36**, local controller **32**, the building automation controller **18**, and/or other controller may provide an instruction to one or more register vents **26** (e.g., an electronically controlled register vent) to adjust a vent damper **30** for the purpose of improving the efficiency of establishing a desired comfort level conditioning setting or for other building conditioning-related purposes in response to obtaining or receiving the analyses from a controller of the HVAC system based, at least in part, on sensed data from local sensors **34** or other sensors. In some cases, the instruction to one or more register vents **26** may be provided to improve uniformity of temperature between spaced sensor locations, between spaced register vent locations, register dampers locations and/or generally within a space, to allow at least a minimum air flow from the HVAC system to help protect the HVAC system from damage, to maintain at least a minimum number of register vent dampers **30** in an open state, and/or for one or more other purposes. An indication of the provided instruction may be sent to the user interface **46** to alert a user of the instruction. In some cases, the controller of the HVAC system may be optionally and/or selectively set to automatically provide an instruction to one or more register vents **26** to adjust its vent damper **30** in response to a received recommendation and/or the controller may be optionally or selectively set to require a confirmation from a user at the user interface **46** before sending an instruction to one or more register vents **26** to adjust its vent damper **30**. In some cases, an instruction may be sent to one or more register vents **26** for execution, and nothing may be sent to the user interface.

The user interface **46** or other user interface may be configured to indicate and/or display one or more suggestions or recommendations from a controller of the HVAC control system for manually setting positions of vent dampers **30** (e.g., a manually adjustable register vent dampers **30a**) of one or more register vents **26** based, at least in part, on sensed data received from local sensors **34** or other sensors. The one or more suggestions may be obtained from one or more controllers of or in communication with the HVAC system of a building **2** (e.g., the controllers may include one or more of the remote system **36**, the local controller **32**, the building automation controller **18**, and/or other controller). The controllers of the HVAC system of the building **2** may base the suggestions for manually setting positions of the vent dampers **30a** at least partially on either or both of area conditioning parameters sensed by a sensor

of the HVAC system and data related to conditioning parameters of one or more HVAC systems in a similar geographic region as a subject HVAC system.

As referred to above, the HVAC system of building **2** may include a plurality of register vents **26**, where all of the plurality of register vents **26** are electronically controlled, all of the plurality of register vents **26** are manually controlled, and/or a portion of the plurality of register vents **26** are electronically controlled and a portion of the register vents **26** are manually controlled. In instances where the plurality of register vents **26** include one or more manually controlled register vents **26**, a controller of or in communication with the HVAC system may suggest to the user a setting for a manually operated register vent **26** (e.g., a position setting for a manually operated vent damper **30a**) to improve uniformity of temperature between spaced sensor locations, between spaced register vent locations, register dampers locations and/or generally within a space, to allow at least a minimum air flow from the HVAC system to help protect the HVAC system from damage, to maintain at least a minimum number of register vent dampers **30** in an open state, and/or for one or more other purposes. In instances where the plurality of register vents **26** include one or more electronically controlled register vents **26**, a controller of or in communication with the HVAC system may suggest a setting for an electronically operated register vent **26** (e.g., a position setting for an electronically controllable vent damper **30b**). In instances where the plurality of register vents **26** include both manually controlled register vents and electronically controlled register vents **26**, a controller of or in communication with the HVAC system may suggest a setting for a manually operable register vent **26** and may request authorization to automatically set the position of the electronically operable register vents **26**.

In response to receiving a suggestion at the user interface **46** for position settings of vent dampers **30** of the register vents **26**, a user may, in some cases, be presented with an option to accept the suggestion, reject the suggestion, or modify the suggestion via the user interface **46**. When the register vents **26** include both electronically controlled and manually controlled vent dampers **30a**, the user interface **46** may provide or display options to accept the suggestion, reject the suggestion, or modify the suggestion with respect to the electronically operable vent dampers **30b**, the manually operable vent dampers **30a**, or both.

When the register vents **26** have manually operable vent dampers **30a**, a user may accept, reject, or modify the position setting suggestion for the manually operable vent dampers **30a** and then either manually adjust the manually operable vent dampers **30a** according to the suggestion or the modified suggestion, or do nothing in the event the suggestion was rejected. After the user has made a selection or confirmation at the user interface **46** with respect to acceptance, rejection, or modification of the suggested position setting for the vent dampers **30**, one or more controllers of the HVAC system may monitor heat gain and/or loss, or other parameter, to determine whether the user positioned the vent dampers **30** consistent with accepting, rejecting, or modifying the suggested position setting of the vent dampers **30**. If no change in heat gain and/or loss, or other parameter, is realized by the controller of or in communication with the HVAC system, the controller may determine no changes were made (which may be consistent with rejecting a suggested vent damper **30** position setting) or that the changes made had no impact. Identification by the controller of or in communication with the HVAC system of either situation may prompt the controller to recommend the

changes again or recommend new changes to the system to try and impact the comfort level conditioning in a space in a desirable manner. Alternatively, the controller may recognize that a user is not interested in obtaining instructions, and refrain from providing further suggestions of position settings for vent dampers **30** for a selected or default period of time.

When the register vents **26** have electronically operable vent dampers **30b**, a user may accept, reject, or modify the position setting suggestion for the electronically operable vent dampers **30b** and then, in response, the controller(s) of or in communication with the HVAC system may automatically effect the position settings of the vent dampers **30**. Alternatively, the controllers of or in communication with the HVAC system may automatically effect any suggestion and provide a confirmation to the user interface **46** of such changes to the position settings of the vent dampers **30**. After a suggestion has been implemented/accepted, rejected, or modified, one or more controllers of the HVAC system may monitor heat gain and/or loss, or other parameter, as discussed above, to determine the effect of the modification of the vent damper position setting on sensed comfort level parameters in the conditioned space. The controller(s) of or in communication with the HVAC system may learn from the monitoring which vent damper **30** position settings may be effective and which are not as effective for improving the operation of the HVAC system over time.

When either or both electronically operable vent dampers **30b** and manually operable vent dampers **30a** are included in a building automation system **4**, the controllers of or in communication with the HVAC system may take into consideration whether a user accepted, rejected, or modified one or more of the suggested position settings for either or both of the manually operable vent dampers **30a** and the electronically operable vent dampers **30b**. For example, if the suggested position settings for the manually operable vent dampers **30a** are rejected and the position settings for the electronically operable vent dampers **30b** are accepted, the controller(s) of or in communication with the HVAC system may modify the suggested position settings taking into account the lack of desire on the part of a user to change the position settings of the manually operable vent dampers **30a**.

The HVAC system may store an indicator of vent damper settings or positions of one or more of the vent dampers **30** in memory **38** or other memory. Additionally or alternatively, the HVAC system may store data sensed by the local sensors **34** or other sensors, sensor locations of the local sensors **34** or other sensors within the building **2**, an indicator of register vent **26** locations within the building **2**, an indicator of register vent damper **30** locations within the building **2**, thermodynamic properties of the building **2**, historical sensed data, and/or other building automation system **4** information. The building automation controller **18** or other controller may determine recommended settings for devices of or related to the HVAC system (e.g., one or more manually adjustable register vent dampers **30a**, etc.) and/or may control device of or related to the HVAC system (e.g., one or more electronically controllable register vent dampers **30b**, etc.) based, at least in part, on the received sensed data, the stored indicators of the sensor locations, the stored indicators of register vent **26** locations within the building **2**, the stored indicators of register vent damper **30** locations within the building **2**, analyses of thermodynamic properties of the building **2**, historical sensed data, other building automation system **4** information, and/or similar or dissimilar HVAC related data from each of a plurality of HVAC systems.

The building automation controller **18** or other controller (e.g., a controller of the remote system **36**) may use stored or other building information (e.g., as discussed above) to make and/or implement recommendations including setting changes to the building automation system **4** and display those recommendations via a user interface. In one example, operation of an HVAC control system may include collecting environmental sensor data via two or more sensing devices located at two or more identified locations within a building. Then, analyzing the collected environmental sensor data in conjunction with the two or more identified locations of the sensors providing the data to determine recommended HVAC component **6** setting changes, if any, based at least partially on the sensed and/or stored data (e.g., collected data) and displaying the recommended setting changes to a user via a user interface that may be associated with the HVAC control system. If no changes are recommended, an indication that no changes were identified may be displayed on the user interface.

In one case, recommended setting changes and/or setting changes based on the sensed and/or stored data may include a manual adjustment to one or more manually adjustable register dampers, an adjustment to one or more electronically controllable register dampers, a suggestion to incorporate an electronically controllable register damper in the building at a particular location, an adjustment to a fan setting of the HVAC system (e.g., changing a mode of the fan between an on mode (e.g., the fan is always running when in this mode), an off mode (e.g., the fan is never runs while in this mode), an auto mode (e.g., when in this mode, the fan runs while the furnace, air conditioner, or other forced air HVAC component is running), a circulate mode (e.g., when in this mode, the fan runs according to a set schedule or a set percentage of the time in addition to running when the furnace, air conditioner, or other forced air HVAC component is running), and/or other modes) and/or other HVAC related recommendations. Such recommended setting changes and/or setting changes may facilitate optimizing a flow of air through a building to adjust a comfort level in the building and/or a specified zone, sub-zone, or area of the building.

In one example of using stored building automation system **4** information, the building automation controller **18** or other controller may be configured to make macro-zone and/or micro-zone adjustments and/or recommendations. When a building is zoned by floors, for example, the building automation controller **18** may be configured to maintain a first comfort level in a first macro zone of a first floor and a second comfort level in a second macro zone of a second floor. By using stored building automation system **4** information (e.g., settings or positions of register vent dampers **30** or other building automation system **4** information) or other information, the building automation controller **18** or other controller may adjust or provide a recommendation to adjust one or more settings (e.g., to adjust a register vent damper **30** setting, change a fan setting of the HVAC system to one of an on mode, an off mode, an auto mode, and a circulation mode, change a position of a window treatment) for a sub-zone or micro-zone within one or more of the first macro-zone and the second macro-zone that may be considered to be more effective than another option based on the stored building automation system **4** information. In some instances, a micro-zone may be established to compensate for a hot spot or cool spot within the macro-zone and/or to allow a user to adjust a comfort level of only a portion of a larger zone.

As discussed, the building automation controller **18** or other controllers may adjust or provide instructions or recommendations for adjusting individual register vent dampers in one or more zones of a building **2**. In one example, the building automation controller **18** may be configured to adjust and/or determine a first recommended setting for one or more register vent dampers **30** (e.g., manually adjustable and/or electronically controllable register vent dampers) that service a first zone of the building **2** and a second recommended setting for one or more register vent dampers **30** (e.g., manually adjustable and/or electronically controllable register vent dampers) that service a second zone of the building **2** based, at least in part, on stored building automation system **4** information and/or other information.

The controllers of or in communication with the HVAC system may continually monitor the impact of suggested and/or implemented adjustments on a performance of the HVAC system (e.g., vent dampers **30** settings, fan **21** settings, etc.). In response to the monitoring of the HVAC system, the controllers of or in communication with the HVAC system may (optionally) automatically adjust settings of the HVAC components **6** and/or recommend or suggest changes to settings of the HVAC components **6**. In some cases, the controllers of the HVAC system may learn from the monitoring of the HVAC system settings and the effect of those settings on a conditioned space, such that the controllers of or in communication with the HVAC system may provide improved suggestions over time.

In one example of controllers of or in communication with an HVAC system that monitor adjustments to the settings of HVAC components and the associated effect on a comfort level of a conditioned space, if any, the controllers may suggest through the user interface **46** that a user closes all vent dampers **30** in a basement, the user set all of the vent dampers **30** on a middle level to a 50% open position, and leave all vent dampers **30** on the upper level fully open. The user then may indicate through the user interface **46** that such suggested changes were made. In the example, the controllers of or in communication with the HVAC system may notice the user changed a sleeping temperature when the HVAC system was in a cooling mode to a higher setting. The controllers of or in communication with the HVAC system may then conclude that the suggested changes and/or changes made were successful and potentially resulted in energy savings due to the allowed higher temperature when the system was in a cooling mode. The controllers (e.g., via the remote system **36**) may then push the suggested HVAC component **6** settings (e.g., settings of vent dampers **30**) to other buildings (e.g., homes) in a community around the monitored building. Additionally, or alternatively, the controllers may store the suggested HVAC component **6** settings for similar situations (e.g., situations taking into account past, current, and expected future thermodynamics of a building **2**, conditions outdoors, etc.) in the future. In some cases, these settings may be automatically applied when similar environmental situations are identified in the future.

In some instances, the remote system **36** may include a remote communications port or block **42**, where the remote communications port or block **42** may be in communication with the processor **40** and the memory **38** of the remote system **36**, along with a local communications port or block **44** of one or more building automation systems **4**. The local communications port or block **44** may be in communication with the local controllers **32** and/or local sensors **34** of the register vents **26**, the building automation controllers **18**, and/or a user interface **46** of the building automation system

4. The local communications port or block **44** may be a part of or may be a separate device from one or more of the local controllers **32** of the register vents **30**, the building automation controllers **18**, the user interface **46**, and/or other device or feature of the building automation system **4**.

The remote system **36** may be a cloud based (e.g., internet connected) system that is configured to connect and/or monitor one or more HVAC systems of one or more related or unrelated buildings. In one instance, the remote system **36** may be configured to monitor the number of register dampers in a building **2** and ensures a requisite amount of air is delivered to one or more conditioned spaces of the building **2**. In an example and similar to as discussed above regarding centralized control, the remote system **36** may attempt to ensure 10%-70%, 20%-60%, 30%-50%, or other appropriate percentage range of the number of register vents **26** in the building are open and fluid is flowing from an HVAC component **6** through the vents **28**. Such monitoring is helpful in preventing and/or mitigating static pressure build up in ductwork of an HVAC system of the building **2** and protecting HVAC components **6** of the HVAC system.

In some instances, the remote system **36** may monitor previous, current, and/or anticipated outdoor conditions. Such monitoring may include, but is not limited to, monitoring temperature, humidity, solar strength, solar position, and/or other outdoor conditions. In response, at least in part, to analyses performed on the outdoor conditions, the remote system **36** may suggest adjusting a position of one or more vent dampers **30** to ensure proper conditioning of all areas of a conditioned space (e.g., a house). In one example, the remote system **36** may determine an expected sun pattern will heat up a south facing side of a building faster than a north facing side at a particular time and thus, the remote system **36** may suggest maintaining vent dampers **30** on the south side of the building **2** in an open position longer during the summer months to cool the conditioned space adjacent the south side of the building **2** and compensate for the predicted solar load. Alternatively, or in addition, to monitoring and/or configuring a position of the vent dampers **30**, the remote system **36** may be configured to adjust one or more HVAC related accessories and/or other accessories in the building that may be able to impact comfort level conditioning in a building or space in an efficient manner. For example, the remote system **36** may suggest that a user opens or closes shades and/or opens or closes windows in response to monitoring an outdoor condition. In instances where a building automation controller **18** is connected to or in communication with building accessories (e.g., window coverings, windows, etc.), the remote system **36** may communicate directly to the connected building accessories to position one or more of those building accessories at a particular setting to more efficiently operate the HVAC system in an economical manner while maintaining comfort for users in the building **2**. In some cases, the remote system **36** may suggest turning on an auxiliary environmental parameter control device (e.g. a window air conditioning unit, a wall air conditioning unit, a portable electric heater, an electric fireplace, a portable electric fan, a ceiling fan, an electric floor heater) to maintain comfort if appropriate. When one or more auxiliary environmental parameter control devices can be controlled by the remote system **36**, the remote system **36** may automatically active/deactivate such auxiliary environmental parameter control devices as appropriate.

The remote system **36** may be configured to monitor past, current, and/or future utility rates and/or usage of gas, electric, water, etc. for and/or at the building **2**. From the

information obtained by monitoring utility rates and/or utility usage, the remote system 36 may communicate with the building automation controller(s) 18 to facilitate operating the HVAC system at an energy efficient level while maintaining comfort for users occupying the conditioned space. In one example, the remote system 36 may suggest the HVAC system utilize a lower cost HVAC component 6 (e.g., electric heaters) when the cost of using an associated type of energy (electricity) is less than the cost of using a different type of energy (e.g., gas) for a different HVAC component (e.g., a gas furnace) that performs a similar conditioning function. The remote system 36 may, in some cases, automatically instruct the HVAC system to utilize a lower cost HVAC component 6 (e.g., electric heaters) when the cost of using an associated type of energy (electricity) is less than the cost of using a different type of energy (e.g., gas) for a different HVAC component (e.g., a gas furnace) that performs a similar conditioning function.

In some cases, the remote system 36, the building automation controller 18, and/or other systems or controllers may monitor an occupancy of the building 2. In one example of monitoring occupancy of the building 2, the remote system 36, the building automation controller 18, and/or other systems or controllers may utilize geofencing, an occupancy sensor, and/or one or more other mechanisms providing occupancy related information and/or data to monitor and/or determine occupancy of the building 2. Through monitoring occupancy of a building 2, such as through geofencing, the remote system 36 may suggest position settings for vent dampers 30 and/or other settings for HVAC components 6 to assist in limiting or minimizing cycling and/or run time of HVAC components 6. Cycling and/or run times may be limited or minimized by running heating and/or cooling operations of the HVAC system at a lower frequency when the building 2 or a space thereof is determined to be unoccupied. Such limiting or minimizing of cycling and/or run time of the HVAC components 6 may reduce the energy usage of the HVAC system, extend the life of one or more of the HVAC components 6, and/or allow zones of a zoned system to sync and operate similar to a non-zoned system. Geofencing may be particularly useful when HVAC components 6 that may be slower to condition a space to a set point (e.g., hydronics) are utilized for conditioning a space because the crossing of a geofence can be utilized to turn the HVAC component 6 on in sufficient time, or use additional HVAC components 6 to assist in reaching the desired set point before the space is expected to be occupied.

Geofencing is a term used to refer to sensing locations of an individual or device (e.g. via a location aware device) with respect to a geographically defined fence that is established a particular distance from the building. When an individual or device leaves the building and advances to a position outside of the particular distance from the building, the location aware device may detect that the user has crossed the geofence and is leaving for some time. Once a user exits the geofence, the building automation controller 18 may be configured to modify the operation of one or more HVAC components 6 (e.g., to a no occupancy profile). When an individual or device is returning to the building and advances to a position inside of the particular distance from the building, the location aware device may detect that the user has crossed the geofence and is returning home. Once a user enters the geofence, the building automation controller 18 may be configured to modify the operation of one or more HVAC components 6 (e.g., to an occupied profile).

In some instances, a system of the building automation system 4 (e.g., remote system 36 or other system) may be configured to create a model of one or more spaces of a building 2 to be controlled with a developed HVAC system configuration created by the remote system 36. Illustratively, a processing module (e.g., the processor 40 of the remote system 36 or processor of a mobile phone, a tablet, a laptop computer, or other computing device) may be configured to execute one or more sets of instructions stored in memory (e.g., the memory 38) to develop an HVAC system configuration for the modeled space(s) of the building 2. Through a user interacting with the remote system 36 via a web portal or other user interface accessible via the user interface 46 (e.g., a user interface of a thermostat, a mobile application, a web site, a PC application, thermostat screen, etc. accessible on a mobile phone, a tablet, laptop computer, or other computing device) of the building automation system 4, an HVAC system configuration for controlling one or more environmental parameters of the one or more spaces of a building 2 may be developed by the processor 40 of the remote system 36. As an alternative to or in addition to using the remote system 36 to create a model of one or more spaces of a building 2 to be controlled with a developed HVAC system configuration, a building automation controller 18 or other electronic device with appropriate software or applications executable thereon may be configured to develop a model for one or more spaces of a building 2 and one or more HVAC system configurations for those spaces. The user interface 46 may be configured to display the developed model for the one or more spaces of the building 2 and/or the one or more HVAC system configurations.

A model of a space and an HVAC system configuration for that space may be developed by the remote system 36 or other system based on building information that at least partially defines an exterior and/or inner structure of at least part of the building including a space to be conditioned and/or controlled, at least in part, by the developed HVAC system configuration, which may be received via a user interface (e.g., the user interface 46) and a communications port or block (e.g., the communications port or block 42). For example, a user may upload or otherwise provide building information (e.g., selection of one of two or more building type options presented via the user interface, photographs of the interior and/or exterior of the building, a 2-dimensional floorplan or layout of at least part of the building, a 3-dimensional model or layout of at least part of the building, building dimensions, current HVAC system confirmation information for the HVAC system of the building (e.g., including, but not limited to, current locations of one or more register vents within the building), non-HVAC device configurations, etc.) to the remote system 36 through the user interface 46 and/or the remote system 36 may obtain the building information from the user's accounts (e.g., social media or photo sharing/storing databases, etc.) and/or publicly available sources. Additionally, or alternatively, controllers of an existing HVAC control system of the building may automatically detect existing sensors, vent dampers, and/or HVAC or non-HVAC devices of the building and use this information in developing a model of the space and HVAC system. Once the building information is received, a processing module (e.g., processor 40) operatively coupled to the user interface 46 may be configured to create a model of the one or more spaces to be conditioned or controlled by a suggested or developed HVAC system configuration, where the model is developed, at least in part, from the received building information.

Additionally, or alternatively, to developing the model based on building information received via the user interface **46**, the processor may be configured to develop the model of the one or more spaces to be controlled and/or conditioned by the developed HVAC system based, at least in part, on information obtained by the processor **40** of the remote system **36**. In some cases, a user may enter instructions at the user interface **46** for the remote system **36** to obtain publicly accessible information and/or information stored in the remote system **36** that relates to the building **2** in which the space to be controlled and/or conditioned is located (e.g., building type information, building dimension, or other information). In some instances, the processor **40** of the remote system **36** may obtain the information from a publicly available database, such as an online mapping database, online real estate databases, online tax records, online municipality records, and the like.

In some cases, the remote system **36** may be configured to communicate with the building automation controller **18**, if the building **2** includes one, to determine what, if any, HVAC component **6** or other local devices **56** are located in the building **2**. If the remote system **36** detects the building includes one or more HVAC components **6**, the processor **40** of the remote system **36** may develop an HVAC configuration for the one or more spaces of the building **2** that may incorporate one or more of the detected HVAC components **6** and/or takes into account one or more of the detected local devices **56**. One example of taking a detection of a local device **56** into account, is to develop an HVAC system configuration that provides a register vent **26** in a room with a stove, but does not place the register vent behind the stove, where the local device **56** is the stove.

The HVAC system configuration developed by the remote system **36** may be displayed on the user interface and may include a two-dimensional and/or three-dimensional model of the building **2** and/or the spaces of the building **2** to be conditioned and/or controlled, an HVAC system layout, and suggested HVAC system products for implementing a suggested HVAC system configuration. Additionally, or alternatively, the developed HVAC system configuration may include one or more devices having environmental parameter sensors (e.g., local sensors **34** or other sensors) and one or more register vents **26** (e.g., register vents with vent dampers), among other HVAC components **6**, where the developed HVAC system configuration may include suggestions to replace specific HVAC system elements (e.g., a suggestion to replace a manually operated vent damper with an electronically controllable register vent). The HVAC system layout developed by the processor **40** may include suggested zone configurations and/or positions of register vents **26** for the one or more spaces to be controlled and/or conditioned. The user interface may be configured to accept selection of a suggested HVAC system configuration and or purchases of suggested HVAC system products of implementing a suggested HVAC system configuration.

The HVAC system configuration for the building **2** developed by the remote system **36** may include one or more HVAC system configuration options. In some cases, the remote system **36** may provide an HVAC system configuration utilizing HVAC components **6** existing in a modeled space of the building **2** and/or a basic HVAC system configuration. In addition, or as an alternative, the remote system **36** may provide one or more advanced level HVAC system configurations that may increase in cost and/or complexity to implement. In some examples, the advanced level HVAC system configurations may include cost estimates and/or time estimates to implement the proposed

advanced level HVAC system configuration in the modeled space, along with estimated benefits of the advanced level HVAC system configurations including, but not limited to, energy conservation, increased comfort, and/or potential utility cost savings. In some instances, the HVAC system configuration for the building **2** that is developed by the remote system **36** may include an ability to order one or more HVAC components **6** of the developed HVAC system via the user interface **46**.

In operation, a method of developing an HVAC system configuration for an HVAC system of a building may include accepting building information via a user interface of a computing device, where the accepted information at least partially defines or provides access to information defining an inner structure of at least part of the building. Such information may include current HVAC system configuration information for the HVAC system of the building. In one instance, the current HVAC system configuration information may include, among other information, a current location of one or more register vents within the building. Based, at least in part, on the accepted building information, a processor may determine one or more suggested HVAC system configuration for the building and the suggested one or more HVAC system configurations may be displayed via the user interface. In some cases, a suggested HVAC system configuration may be accepted or rejected and products for implementing an accepted suggested HVAC system configuration may be purchased via the user interface.

FIG. **6** depicts example features that may be included in various levels of HVAC configurations that the remote system **36** or other device may develop for a modeled spaced. For example, LEVEL 1 may include a typical thermostat (e.g., a building automation controller **18**) that may allow for control of temperature, fan operation, humidity, and/or ventilation of an HVAC system. LEVEL 2 may include an internet connected thermostat (e.g., a thermostat that may be able to access the remote system **36** and/or wired or wirelessly connected local devices **56**), all of the features of LEVEL 1, remote control of the thermostat from a computing device (e.g., mobile phone, laptop computer, desktop computer, tablet computer, etc.), alerts to the thermostat and/or a computing device (e.g., remote alerts), where the alerts may include, but are not limited to, temperature alerts if temperature in a space increases above or decreases below one or more threshold levels, humidity alerts if humidity in a space increases above or decreases below one or more threshold levels, connection lost alerts if the thermostat loses internet connection, and/or replacement alerts if an HVAC component **6** needs replacement (e.g., filter replacement alerts, etc.). LEVEL 3 may include an internet connected thermostat, remote control of the thermostat from a computing device, wired or wireless space/zone sensors, all of the features of LEVEL 2, along with the ability for the thermostat (or a remote system **36** connected to the thermostat) to perform thermodynamics by one or more rooms and/or spaces of a building **2**. The thermodynamics analyses may analyze, among other parameter data, temperature data, humidity data, air quality data, etc., and provide recommendations for HVAC component **6** settings, including, but not limited to manually implemented settings for fans, dampers **24** (e.g., duct-line dampers and/or vent dampers **30**), window treatments, and/or various other devices that may affect comfort level conditioning in the monitored zones or spaces and may be manually adjustable. LEVEL 4 may include an internet connected thermostat, remote control of the thermostat from a computing device, wired or wireless space/zone sensors, vent dampers **30**, all of

the features of LEVEL 3, along with automated comfort control of fan operation, temperature, humidity, air quality, and/or other comfort level conditioning affecting parameters. With LEVEL 4 the thermodynamics analyses may be utilized to selectively and/or automatically establish set points and/or control over the fan operation, temperature set points, humidity set points, air quality control components, and/or other components configured to affect comfort level conditions of the zones or spaces. LEVEL 5 may include an internet connected thermostat, remote control of the thermostat from a computing device, wired or wireless space/zone sensors, vent dampers **30**, automation of one or more local devices **56** (e.g., window treatments, windows, portable heating/cooling components, locks, lights, sound, water faucets, refrigerators, stoves, ovens, etc.), and all of the features of LEVEL 4. The thermodynamics analyses in a LEVEL 5 system may be utilized to selectively and/or automatically establish set points and/or control over local devices **56** including, but not limited to, window treatments, windows, portable heating/cooling components, locks, lights, sound, water faucets, refrigerators, stoves, ovens, etc.

Although examples of five levels of HVAC system configuration components are described above, other components may be included or excluded at any of the levels of HVAC system configurations in view of a modeled space to be comfort level conditioned and/or in view of other considerations. For example, if a space is already conditioned based on components of a LEVEL 3 configuration described above, a level 3 configuration may be a baseline configuration and one or more levels (e.g., 1, 2, 3, 4, 5, 10, 20, and so on) of HVAC system configuration components may be provided to a user that may be used to incrementally decrease energy consumption. Illustratively, if a space is already conditioned with an HVAC system configuration that is substantially completely automated, a suggested next level of HVAC system configuration componentry may include suggesting a user utilize renewable energy to reduce energy consumption by the HVAC system configuration through incorporating one or more of solar panels, geothermal heating/cooling, etc. into the HVAC system configuration of the comfort level conditioned space. In some cases, a plurality of HVAC system configuration options are provided, sorted by the expected cost/benefit for each option.

Having thus described several illustrative embodiments of the present disclosure, those of skill in the art will readily appreciate that yet other embodiments may be made and used within the scope of the claims hereto attached. Numerous advantages of the disclosure covered by this document have been set forth in the foregoing description. It will be understood, however, that this disclosure is, in many respects, only illustrative. Changes may be made in details, particularly in matters of shape, size, and arrangement of parts without exceeding the scope of the disclosure. The disclosure's scope is, of course, defined in the language in which the appended claims are expressed.

What is claimed is:

1. An HVAC control system configured to control an HVAC system of a building, the HVAC system including a fan configured to provide conditioned air to one or more HVAC ducts of the building, a plurality of register vents configured to deliver the conditioned air from the one or more HVAC ducts into the building, and two or more electronically controllable dampers, each of the two or more electronically controllable dampers being associated with at least one of the two or more register vents, the HVAC control system comprising:

a communications block configured to receive one or more requests for conditioned air; and

a controller operatively coupled to the communications block, the controller configured to receive signals related to one or more local conditions in the building via the communications block, and in response:

determine a damper setting for at least one of the two or more electronically controllable dampers based, at least in part, on a damper setting for another one or more of the two or more electronically controllable dampers such that a sum of damper opening sizes of the two or more electronically controllable dampers remains above a minimum damper opening size threshold when the fan is activated; and

communicate the determined damper setting to the at least one of the two or more electronically controllable dampers via the communications block.

2. The HVAC control system of claim **1**, wherein the communications block comprises a wireless interface.

3. The HVAC control system of claim **2**, wherein at least one of the two or more electronically controllable dampers is in communication with a wireless interface configured to communicate requests for conditioned air to the wireless interface of the communications block.

4. The HVAC control system of claim **1**, wherein the fan is part of a forced air HVAC system.

5. The HVAC control system of claim **1**, wherein the fan is part of a ventilation unit configured to bring outside air into the building and exhaust inside air from the building.

6. The HVAC control system of claim **1**, wherein the HVAC system includes one or more of a forced air furnace or an air conditioner.

7. The HVAC control system of claim **1**, wherein the HVAC system includes one or more of an electric heater, a fireplace, a portable electric fan, a ceiling fan, or a floor heater.

8. The HVAC control system of claim **1**, wherein the HVAC system comprises one or more sensors configured to sense the one or more local conditions in the building and provide the signals related to the one or more local conditions to the controller via the communications block.

9. The HVAC control system of claim **1**, wherein the HVAC system of the building is a zoned HVAC system, and wherein at least a first damper of the two or more electronically controllable dampers corresponds to a first zone and at least a second damper of the two or more electronically controllable dampers corresponds to a second zone, and wherein the controller is configured to control the first zone differently from the second zone.

10. An HVAC control system configured to control an HVAC system of a building, wherein the HVAC system comprises a forced air conditioning system with a fan and includes ducts configured to carry air of the forced air conditioning system, a plurality of register vents in fluid communication with the ducts, two or more electronically controllable dampers, each of the two or more electronically controllable dampers having an electronically controllable damper opening size, the HVAC control system comprising:

two or more sensors configured to sense an environmental parameter at two or more different locations in the building; and

a controller in operative communication with the two or more sensors, the two or more electronically controllable dampers, and one or more HVAC components of the forced air conditioning system,

the controller being further configured to control the one or more HVAC components of the forced air condi-

25

tioning system and a damper opening size of at least one of the two or more electronically controllable dampers based, at least in part, on:

the sensed environmental parameters; and

a damper opening size for another one or more of the two or more electronically controllable dampers such that a sum of damper opening sizes of the two or more electronically controllable dampers remains above a minimum damper opening size threshold when the fan is activated.

11. The HVAC control system of claim 10, wherein the sensed environmental parameters comprises a parameter other than temperature.

12. The HVAC control system of claim 11, wherein the controller is configured to:

receive a request for data related to the sensed environmental parameters; and

provide a report for the data related to the sensed environmental parameters other than temperature based, at least in part, on the stored values of the sensed environmental parameters other than temperature.

13. The HVAC control system of claim 10, wherein:

the forced air conditioning system is a zoned system with a first of the two or more electronically controllable dampers in a first zone and a second of the two or more electronically controllable dampers in a second zone, at least a first sensor of the two or more sensors is in the first zone and at least a second sensor of the two or more sensors is in the second zone, and

the controller is configured to control the first zone differently from the second zone based on the first sensor and the second sensor.

14. The HVAC control system of claim 10, wherein the fan is part of a ventilation unit configured to bring outside air into the building and exhausting inside air from the building.

15. An HVAC control system configured to control a zoned HVAC system of a building, the zoned HVAC system including one or more HVAC components configured to provide conditioned air to one or more HVAC ducts of the building, the one or more HVAC components including a fan and a plurality of electronically controllable dampers configured to control delivery of the conditioned air from the one or more HVAC ducts into each of two or more zones of the building, each of the two or more zones of the building having at least one sensor for sensing a sensed condition in the corresponding zone, the HVAC control system comprising:

26

a communications block configured to receive a measure related to the sensed condition from each sensor in the two or more zones of the building; and

a controller operatively coupled to the communications block, the controller configured to receive the measures related to the sensed condition from each of sensors via the communications block, and in response:

electronically control a damper opening size of each of the plurality of electronically controllable dampers in accordance with a damper setting;

determine a damper setting for a first damper of the plurality of electronically controllable dampers based, at least in part, on a damper setting for a second damper of the plurality of electronically controllable dampers such that a sum of the damper opening sizes of the plurality of electronically controllable dampers remains above a minimum damper opening size threshold when the fan is activated;

transmit, via the communications block, the determined damper setting for the first damper of the plurality of electronically controllable dampers to the first damper; and

provide one or more control signals to activate at least one of the one or more HVAC components.

16. The HVAC control system of claim 15, wherein the sensed condition comprises temperature.

17. The HVAC control system of claim 15, wherein the sensed condition comprises a parameter other than temperature.

18. The HVAC control system of claim 15, wherein the zoned HVAC system includes at least a first sensor in a first zone of the two or more zones and at least a second sensor in a second zone of the two or more zones, and wherein the controller is configured to control the first zone differently from the second zone based on a first measure of the sensed condition received from the first sensor and a second measure of the sensed condition received from the second sensor.

19. The HVAC control system of claim 15, wherein the fan is part of a forced air HVAC system.

20. The HVAC control system of claim 15, wherein the fan is part of a ventilation unit configured to bring outside air into the building and exhaust inside air from the building.

* * * * *