

US009932966B2

(12) **United States Patent**
Gomís Bellmunt et al.

(10) **Patent No.:** **US 9,932,966 B2**
(45) **Date of Patent:** ***Apr. 3, 2018**

(54) **METHOD FOR AVOIDING VOLTAGE INSTABILITY IN AN ELECTRICAL GRID OF AN OFFSHORE WIND PARK**

(52) **U.S. Cl.**
CPC **F03D 7/048** (2013.01); **F03D 7/00** (2013.01); **F03D 7/0284** (2013.01); **F03D 9/257** (2017.02);

(71) Applicant: **ALSTOM RENEWABLE TECHNOLOGIES**, Grenoble (FR)

(Continued)

(72) Inventors: **Oriol Gomís Bellmunt**, Barcelona (ES); **Mónica Aragüés Peñalba**, Barcelona (ES)

(58) **Field of Classification Search**
CPC H02J 3/386; H02J 3/16; H02J 3/06; H02J 3/18; H02J 3/381; H02J 3/40;
(Continued)

(73) Assignee: **GE Renewable Technologies Wind B.V.**, Breda (NL)

(56) **References Cited**

U.S. PATENT DOCUMENTS

(*) Notice: Subject to any disclaimer, the term of this patent is extended or adjusted under 35 U.S.C. 154(b) by 271 days.

5,642,000 A 6/1997 Jean-Jumeau et al.
6,738,719 B2 5/2004 Stoupis et al.
(Continued)

This patent is subject to a terminal disclaimer.

FOREIGN PATENT DOCUMENTS

DE 10 2004048341 4/2006

(21) Appl. No.: **14/800,608**

OTHER PUBLICATIONS

(22) Filed: **Jul. 15, 2015**

International Search Report and Written Opinion for PCT/EP/2013/053029, dated Jun. 5, 2013, 10 pgs.

(65) **Prior Publication Data**

(Continued)

US 2016/0010626 A1 Jan. 14, 2016

Primary Examiner — Darrin Dunn

Related U.S. Application Data

(74) *Attorney, Agent, or Firm* — Dority & Manning, P.A.

(63) Continuation of application No. 14/375,771, filed as application No. PCT/EP2013/053029 on Feb. 14, 2013, now Pat. No. 9,124,134.

(Continued)

(57) **ABSTRACT**

Method for avoiding voltage instability in an electrical grid of an offshore wind park, the offshore wind park electrical grid being connected at a first end of a high voltage alternating current (HVAC) transmission and the main land electrical grid being connected at a second end of the HVAC transmission, each of the wind turbines being connected to the wind park electrical grid, the method comprises determining a main land phase angle at or near the second end of the HVAC transmission; measuring an individual wind turbine phase angle at one or more wind turbines; determining the difference between each of the measured individual wind turbine phase angles and the main land phase angle;

(Continued)


(30) **Foreign Application Priority Data**

Feb. 16, 2012 (EP) 12382051

(51) **Int. Cl.**

G05D 3/12 (2006.01)
F03D 7/04 (2006.01)

(Continued)



and determining whether the difference between one of the measured individual wind turbine phase angle and the main land phase angle exceeds a threshold phase angle difference.

13 Claims, 1 Drawing Sheet

Related U.S. Application Data

(60) Provisional application No. 61/624,884, filed on Apr. 16, 2012.

(51) **Int. Cl.**
H02J 3/24 (2006.01)
H02J 3/38 (2006.01)
F03D 7/02 (2006.01)
F03D 7/00 (2006.01)
G01R 25/00 (2006.01)
G05B 15/02 (2006.01)
F03D 9/25 (2016.01)

(52) **U.S. Cl.**
 CPC *G01R 25/005* (2013.01); *G05B 15/02* (2013.01); *H02J 3/24* (2013.01); *H02J 3/386* (2013.01); *F05B 2240/95* (2013.01); *Y02E 10/723* (2013.01); *Y02E 10/763* (2013.01)

(58) **Field of Classification Search**
 CPC Y02E 10/763; Y02E 40/30; Y02E 10/566; Y02E 40/72; F03D 7/0284; F03D 7/0272; F05B 2270/337; F05B 2240/95; H02P 2101/15

See application file for complete search history.

(56) **References Cited**

U.S. PATENT DOCUMENTS


6,864,595 B2 * 3/2005 Wall H02J 3/38 290/52
 7,498,821 B2 3/2009 Wells
 7,542,256 B2 * 6/2009 Premerlani H02H 7/30 324/522
 7,603,203 B2 10/2009 Zhang et al.
 8,340,931 B2 12/2012 Dickens
 8,378,515 B2 2/2013 Fortmann
 8,942,856 B2 1/2015 Ren et al.
 9,124,134 B2 * 9/2015 Gomis Bellmunt H02J 3/24
 9,366,227 B2 * 6/2016 Garcia H02J 3/18
 2001/0012211 A1 * 8/2001 Hasegawa H02J 3/16 363/131
 2002/0149375 A1 10/2002 Hu et al.
 2003/0007369 A1 * 1/2003 Gilbreth H02J 1/10 363/35
 2003/0011348 A1 * 1/2003 Lof H02J 3/381 322/37
 2003/0081364 A1 5/2003 Stoupis et al.
 2004/0010350 A1 1/2004 Lof et al.
 2007/0035136 A1 * 2/2007 Janssen F03D 9/255 290/44
 2007/0090651 A1 * 4/2007 Wobben F03D 7/0272 290/44
 2007/0096747 A1 5/2007 Wells
 2008/0073912 A1 3/2008 Fortmann et al.
 2008/0150283 A1 * 6/2008 Rivas H02J 3/1885 290/44
 2009/0021014 A1 * 1/2009 Letas H02J 3/386 290/44
 2009/0033096 A1 * 2/2009 Jurkat F03D 7/028 290/44

2009/0167021 A1 * 7/2009 Andersen F03D 7/0284 290/44
 2009/0206606 A1 * 8/2009 Jorgensen F03D 7/0224 290/44
 2010/0148508 A1 * 6/2010 Garcia H02J 3/16 290/44
 2010/0276930 A1 * 11/2010 Fortmann F03D 9/255 290/44
 2010/0276931 A1 * 11/2010 Wobben F03D 7/0272 290/44
 2010/0327599 A1 * 12/2010 Nielsen H02P 9/10 290/55
 2011/0022240 A1 * 1/2011 Rajapaske G05B 23/0254 700/287
 2011/0082654 A1 4/2011 Dickens
 2011/0109085 A1 * 5/2011 Nelson H02J 3/24 290/44
 2011/0140428 A1 * 6/2011 Wakata F03D 7/0284 290/44
 2011/0282508 A1 * 11/2011 Goutard H04L 63/20 700/293
 2011/0304141 A1 * 12/2011 Van Dyck H02J 3/1878 290/44
 2012/0010755 A1 * 1/2012 Stapelfeldt F03D 7/0284 700/287
 2012/0061964 A1 * 3/2012 Kirchner F03D 7/0284 290/44
 2012/0086459 A1 4/2012 Kim
 2012/0112713 A1 5/2012 Kuehn
 2012/0181879 A1 * 7/2012 Andresen H02J 3/02 307/151
 2012/0280569 A1 11/2012 Alam et al.
 2012/0280665 A1 * 11/2012 Su H02M 1/32 322/89
 2012/0310426 A1 * 12/2012 Tarnowski F03D 7/0272 700/287
 2013/0043690 A1 * 2/2013 Wilson H02J 3/1807 290/40 B
 2013/0073109 A1 * 3/2013 Cheng H02J 3/40 700/298
 2013/0140820 A1 * 6/2013 Tarnowski F03D 7/0284 290/44
 2013/0140903 A1 6/2013 Divan et al.
 2013/0241201 A1 * 9/2013 Fortmann H02J 3/26 290/44
 2013/0265030 A1 10/2013 Kuroda et al.
 2013/0265809 A1 * 10/2013 Gupta H02J 3/386 363/131
 2013/0270827 A1 * 10/2013 Couchman F03D 7/028 290/44
 2014/0043080 A1 * 2/2014 Larsen H02M 5/42 327/243
 2014/0062086 A1 * 3/2014 Mata Dumenjo H02J 3/1842 290/44
 2015/0042093 A1 2/2015 Gomis Bellmunt et al.
 2016/0010626 A1 * 1/2016 Gomis Bellmunt H02J 3/24 700/287

OTHER PUBLICATIONS

Augustí Egea-Alvarez et al., "Active and Reactive Power Control of Grid Connected Distributed Generation Systems", Modeling and Control of Sustainable Power Systems, Green Energy and Technology, pp. 47-81 (2012).
 Glavic et al., "A short Survey of Methods for Voltage Instability Detection", Power and Energy Society General Meeting IEEE, 8 pgs. (2011).
 Nizam et al. "Performance Evaluation of Voltage Stability Indices for Dynamic Voltage Collapse Prediction", J. of Applied Science 6 (5) pp. 1104-1113 (2006).

* cited by examiner



**METHOD FOR AVOIDING VOLTAGE
INSTABILITY IN AN ELECTRICAL GRID OF
AN OFFSHORE WIND PARK**

This application claims the benefit of European Patent Application EP12382051, filed on Feb. 16, 2012, and of U.S. Provisional Patent Application Ser. No. 61/624,884, filed on Apr. 16, 2012.

The present invention relates to methods for avoiding voltage instability in offshore wind parks.

BACKGROUND ART

Modern wind turbines are commonly used to supply electricity into the electrical grid. Wind turbines of this kind generally comprise a rotor with a rotor hub and a plurality of blades. The rotor is set into rotation under the influence of the wind on the blades. The rotation of the rotor shaft either directly drives the generator rotor ("directly driven") or through the use of a gearbox.

An important trend in the field of wind turbines is to place the turbines in offshore wind parks. These wind parks comprise a plurality of wind turbines and a local wind park grid. This wind park grid may be connected to an onshore electrical grid through a High Voltage Alternating Current (HVAC) transmission.

In known HVAC transmission systems voltage instability problems may occur which may cause a voltage collapse in case of severe disturbances, like deep voltage sags. Voltage stability may be defined as the ability of a power system to maintain steady acceptable voltages at all buses in the system under normal operating conditions and after being subjected to a disturbance.

A system may enter a state of voltage instability when a disturbance, an increase in load demand, or a change in system conditions, cause a progressive and uncontrollable drop in voltage. An important factor causing instability is the inability of the power system to meet the demand for reactive power. At the heart of the problem is usually the voltage drop that occurs when active and reactive power flow through inductive reactances associated with the transmission network.

Voltage instability is a local phenomenon; however, its consequences may have a widespread impact. Voltage Collapse is more complex than simple voltage instability and is usually the result of a sequence of events accompanying voltage instability leading to a low-voltage profile in a significant part of the power system. Solutions that only take into account local voltages may not be good enough to predict and/or prevent voltage collapse for electrical grids involving offshore wind parks.

The prediction of voltage instabilities with enough anticipation in order to avoid damaging consequences is fundamental. In this respect, it is known to use a Voltage Collapse Prediction Index (VCPI) consisting of calculating this index at every bus of the power system in offshore wind parks. The calculation of this VCPI requires to have voltage phasor information of the buses in the system and to know the network admittance matrix. The value of VCPI may determine the proximity to voltage collapse at a specific bus. A disadvantage is that the index used is rather complex and the information necessary to use it may not even be available to wind park operators.

In this respect, a simpler index that is able to assist in avoiding voltage collapse is desired.

SUMMARY OF THE INVENTION

In a first aspect, the invention provides a method for avoiding voltage instability in an electrical grid of an

offshore wind park, wherein the offshore wind park electrical grid is connected at a first end of a high voltage alternating current transmission and the main land electrical grid is connected at a second end of the high voltage alternating current transmission, and wherein the wind park has a plurality of wind turbines. The method comprises determining a main land phase angle at or near the second end of the high voltage alternating current transmission and measuring an individual wind turbine phase angle at one or more wind turbines. The method further comprises determining a threshold phase angle difference, determining the difference between each of the measured individual wind turbine phase angles and the main land phase angle and determining whether the difference between one of the measured individual wind turbine phase angle and the main land phase angle exceeds the threshold phase angle difference.

It has been found that the difference between the phase angle at an individual wind turbine and the phase angle at the onshore end of the HVAC may be used to indicate when a situation close to voltage instability (and voltage collapse) arises. Whenever this phase angle difference surpasses a threshold value, a warning may be obtained and/or preventive actions may be undertaken. An advantage of using this phase angle difference is that it is relatively simple and easy to implement. A further advantage is that it has been found to be reliable for avoiding voltage instability.

In some embodiments, determining the main land phase angle comprises measuring a phase angle at or near the first end of the high voltage alternating current transmission and calculating the main land phase angle at the second end based on a model of the high voltage alternating current transmission. Alternatively, the phase angle may be measured at the second end of the HVAC transmission. This information may then be sent through a suitable communications network (e.g. optical fiber) to the offshore wind park.

In an implementation, wherein there is no such communication system between the offshore wind park electrical grid and the main land electrical grid, the main land phase angle may be computed at the first end of the high voltage alternating current transmission. In order to achieve this, a phase angle may be measured at or near the first end of the high voltage alternating current transmission. Next the main land phase angle may be estimated based on the measured phase angle at the first end of the HVAC and on the model of the HVAC transmission system. This model may comprise the electrical parameters of HVAC transmission line. These parameters may permit to calculate the phasor of the voltage at the main land electrical grid. The main land phase angle may be obtained from this phasor.

In some embodiments, if a difference between at least one individual wind turbine phase angle and the main land phase angle exceeds the threshold phase angle, the active power generated by all the wind turbines of the wind park is reduced. A relatively high value of the phase angle difference may indicate that the HVAC is close to its limits, so that in as far as possible, the active power generated by the wind turbines is reduced without completely disconnecting the turbines.

In some embodiments, if a difference between at least one individual wind turbine phase angle and the main land phase angle exceeds the threshold phase angle, the reactive power provided by one or more of the wind turbines is adjusted.

In some embodiments, one or more AC reactors may be provided at or near the first end and/or at or near the second end of the high voltage alternating current transmission for optimizing the power flow across the HVAC. In these

embodiments, the AC reactors may be disconnected if a difference between the first angle at or near the first end and the main land phase angle exceeds the threshold phase angle.

The AC reactors located at or near the first end and/or at or near the second end of the high voltage alternating current transmission may consume reactive power to compensate the capacitive reactive power from the cables.

Therefore, if a difference between the first angle at or near the first end and the main land phase angle exceeds the threshold phase angle, it may be suitable to disconnect these reactors in order to avoid larger reactive power consumption in the power system.

Additional objects, advantages and features of embodiments of the invention will become apparent to those skilled in the art upon examination of the description, or may be learned by practice of the invention.

BRIEF DESCRIPTION OF THE DRAWINGS

Particular embodiments of the present invention will be described in the following by way of non-limiting examples, with reference to the appended drawings, in which:

FIG. 1 illustrates a general control scheme according to an embodiment of the present invention;

DETAILED DESCRIPTION OF EMBODIMENTS

FIG. 1 shows a schematic representation of a general control scheme of a power system according to an embodiment of the present invention. FIG. 1 shows an offshore wind park comprising a generating unit or wind turbine 127, which in this embodiment may be a permanent magnet synchronous machine (PMSM). The generator of the wind turbine may be connected to a Back-to-Back converter comprising two voltage source converters: machine side converter 117 (MSC) and grid side converter 116 (GSC), and a DC link 126. Further shown is a control unit 114 which controls the wind turbine 127. The already-mentioned elements are connected to a medium voltage transformer 115 and a medium voltage transmission line 128.

A point of common coupling (PCC) of the offshore wind park 115 connects the offshore wind park with the first end of a high voltage alternating current (HVAC) transmission 109 which comprises a high voltage transformer 129 and AC reactors 113. The AC reactors 113 may be controlled by the AC compensations disconnection control unit 110. A point of common coupling (PCC) onshore 107 connects the second end of the HVAC transmission 109 which comprises a high voltage transformer 130 and AC reactors 106 to an onshore electrical grid 101 and a STATCOM 102 or a similar regulating device, such as e.g. a Static Var Compensator (SVC). The AC reactors 106 may be controlled by the AC compensations disconnection control unit 105.

The AC reactors and STATCOM generally may have the role of optimizing the power flow through the HVAC as well as providing the referenced reactive power to the grid according to the applicable grid code.

The prediction of voltage instability before it happens and in response, performing some actions to avoid the mentioned voltage instability, which could lead to a voltage collapse, is highly desirable. Prediction of voltage instability is meant to be understood as the capacity for determining that voltage instability may occur in a short period of time but it has not happened yet. It has been found that, in order to predict voltage instability the difference in voltage angle

between the onshore end of the HVAC and buses in the wind park is a reliable indicator. This difference is determined in accordance with:

$$\delta = |\delta_i - \delta_j|$$

Wherein δ_i is the angle of the voltage phasor at bus i, δ_j is the angle of the voltage phasor at bus j.

In the current embodiment, an index that is based on the difference in voltage angles is proposed. This index may be called ADI (Angular Difference Index) and may be determined in accordance with the following equation:

$$ADI_{ij} = \frac{|\delta_i - \delta_j|}{\delta_{lim}}$$

Wherein δ_{lim} is the angle that determines maximum active power transmission (90°, theoretically). The value of ADI may vary between 0 and 1 and it may predict the proximity to voltage collapse at a specific bus. If $ADI_{ij}=0$, the voltage at a specific bus i is considered stable and if $ADI_{ij}=1$ a voltage collapse may occur.

Thus, based on ADI, when $\delta = |\delta_i - \delta_j|$, reaches the theoretic limit of 90°, the maximum active power deliverable is achieved, $ADI_{ij}=1$ and voltage collapse may occur. But, in fact, in accordance with circumstances, the limit may be set at a different level. For example, a critical angular difference $\delta_{critical}$ (e.g. 83°) may be defined. In this respect, if $\delta = |\delta_i - \delta_j| \geq \delta_{critical}$ voltage instability is predicted.

Based on the above, when voltage instability is predicted ($|\delta_i - \delta_j| \geq \delta_{critical}$) some actions to avoid the mentioned voltage instability which could lead in a voltage collapse may be performed as shown below:

Control Implemented in the Voltage Source Converters of the Back-to-Back Converter Once Voltage Instability is Predicted:

Once voltage instability is predicted, one suitable response may be to reduce the active power delivered by the generating unit or wind turbine 127 and to adequate the reactive power injection. In this respect, when voltage instability is predicted, the wind turbine 127 may keep generating power during the disturbances associated to the voltage instability state. In this embodiment, a DC chopper 108 is provided. Both the DC chopper 108 and the voltage source converters: machine side converter 117 and grid side converter 116 of a Back-to-Back converter connected to the wind turbine 127 may be used to regulate the active and reactive power.

The prediction of voltage instability at wind turbine 127 is based on the aforementioned index ADI. The ADI particularized for the wind turbine 127 may be called ADI_{k0} and may be determined in accordance with the following equation:

$$ADI_{k0} = \frac{|\delta_k - \delta_0|}{\delta_{lim}}$$

Wherein δ_k is the angle of the voltage phasor at the bus where the wind turbine k (for this embodiment, wind turbine 127) may be connected. The angle δ_k may be calculated with the Phase Lock Loop (PLL) 118. The angle δ_0 may be calculated with the PLL unit 103 at or near the second end of the high voltage alternating current transmission 109 generally measured at the point of common coupling (PCC) 107. The angle δ_{lim} is the angle when maximum active

5

power is transmitted and may be set at the theoretical maximum of 90°, but may also be set at a different, more conservative level. It will be clear that the index may be calculated for a plurality or all of the wind turbines in a wind park.

A critical angular difference $\delta_{critical}$ (e.g. approximately 60°, 70° or 80°) may be defined and if $\delta = |\delta_k - \delta_0| \geq \delta_{critical}$, then voltage instability is predicted and several actions to avoid voltage instability are performed.

The box **114** of FIG. 1 delimits the control unit which controls the wind turbine **127**.

Once the voltage instability is predicted ($|\delta_k - \delta_0| \geq \delta_{critical}$), another action that may be carried out is the computation of the definite references currents I_q^* and I_d^* to be applied in the wind turbine **127**. To obtain these reference currents, reference active power P^* and reference reactive power Q^* may be computed in accordance with:

$$P^* = P_{ref} \cdot \alpha_P$$

$$Q^* = Q_{ref} \cdot \alpha_Q$$

Wherein P^* is the desired active power, Q^* is the desired reactive power, P_{ref} and Q_{ref} are the references of active power P and reactive power Q in a normal condition respectively, α_P and α_Q is a reduction parameter that may be computed as follows:

$$\text{if } ADI_{ko} < ADI_{ko_o} \text{ and } V > Vsag \rightarrow$$

$$\alpha_P = 1, \alpha_Q = 1$$

$$\text{if } ADI_{ko} \geq ADI_{ko_o} \text{ or } V \leq Vsag \rightarrow$$

$$\alpha_P = \max(0, k1p \cdot (1 - ADI_{ko}) + k2p \cdot (1 - V))$$

$$\alpha_Q = \max(0, k1q \cdot (1 - ADI_{ko}) + k2q \cdot (1 - V))$$

Wherein ADI_{ko} , is the stability index at wind turbine k (for this embodiment, wind turbine **127**), ADI_{ko_o} is an adjustable parameter (0.2-0.4), V is the local voltage in the generating machine (p.u.), $Vsag$ is an adjustable parameter (p.u.) indicative of the maximum acceptable voltage sag and $k1p$, $k2p$, $k1q$ and $k2q$ are adjustable weights. Based on the above, it must be noted that verifying that the local voltage V is lower than a predetermined value $Vsag$ may be an additional verification which may predict voltage instability or other problems in the electrical grid.

When $ADI_{ko} \geq ADI_{ko_o}$ or $V \leq Vsag$, α_P and α_Q takes the maximum value among 0 and $k1q \cdot (1 - ADI_{ko}) + k2q \cdot (1 - V)$ to avoid negative values. In this embodiment, the local voltage is thus also taken into account. In other implementation, this does not necessarily need to be the case.

Once the desired active and reactive power P^* and Q^* are obtained, the definite references currents and I_q^* and I_d^* in reference qd may be computed in the reference current computation units **122**. The voltages of the AC side of the converters **117** and **116** in reference qd called V_{lq} , V_{ld} may then be obtained from calculus derived from currents I_q^* and I_d^* effectuated in reference current limitation modules **123**, current loops modules **124**, Park modules **119** and SVM modules **125**. Once the voltages V_{lq} , V_{ld} have been obtained, they may be applied to the voltage source converters **117** and **116** within the Back-to-Back converter in order to control the reactive power and the torque of the wind turbine **127** with the voltage source converter **117** and to control the voltage in the DC link **126**, and to generate or consume reactive power with the voltage source converter **116**.

6

Control Performed by the DC Chopper Once Voltage Instability is Predicted:

In order to help to achieve power reduction, the DC chopper **108** of the generating machine whose bus is close to voltage instability may be activated. The current through the resistance of the DC chopper **108** will correspond to the overvoltage of the DC bus connecting the voltage source converters **117** and **116** in accordance with:

$$I_{ch} = k \frac{E_{dc} - E_{min}}{E_{max} - E_{min}} \leftrightarrow E_{dc} \geq E_{min}$$

Wherein I_{ch} is the current through the chopper **108**, E_{dc} is the voltage of the DC bus of the Back-to-Back converter, and E_{max} and E_{min} are the maximum and minimum values for the actuation of the chopper **108**. In case where voltage instability is predicted ($|\delta_k - \delta_0| \geq \delta_{critical}$), E_{dc} may exceed the value E_{min} and if this situation arises, the chopper may be activated by acting on the chopper transistor so that current I_{ch} may be applied to the chopper resistance in order to contribute to reduce active power injection into the grid. Possible Additional Control Implemented by the AC Compensations Disconnection Control Units Once Voltage Instability is Predicted:

AC reactors **113,106** may be installed at the first and second end of the high voltage alternating current transmission **109** respectively and they may be controlled by the AC compensations disconnection control units **110,105**, respectively.

In response to the prediction of a voltage instability, a further possible action is the simultaneous disconnection of the AC reactors **113, 106** by the control units **110,105** in order to avoid larger reactive power consumption. The power system must find out when it is required to disconnect the AC reactors **113, 106** in order to avoid a possible voltage instability state. In this respect, voltage instability must be predicted. The prediction may be based on the verification of the ADI index. In this case, the ADI may be determined individually for the AC reactors; ADI_{ao} may be determined in accordance with the following equation:

$$ADI_{ao} = \frac{|\delta_a - \delta_0|}{\delta_{lim}}$$

Wherein δ_a may be calculated with the PLL unit **112** at or near the first end of the high voltage alternating current transmission **109** and it may be the angle of the voltage phasor at the bus where the offshore wind park AC compensations are connected. The angle δ_0 may be calculated with the PLL unit **103** at or near the second end of the high voltage alternating current transmission **109** generally measured at the point of common coupling (PCC) **107**. The angle δ_{lim} is the angle that permits maximum active power transmission.

The value of ADI_{ao} varies between 0 and 1 and it determines the proximity to voltage collapse at a specific bus. If $ADI_{ao} = 0$, the voltage at a specific bus a is considered stable and if $ADI_{ao} = 1$ a voltage collapse may occur. The verification required to predict voltage instability in the power system and in response, disconnecting the AC reactors (**113, 106**) to avoid a larger reactive power consumption is based on determining when the difference between δ_a and δ_0 called δ exceeds a threshold phase angle $\delta_{critical}$. In this respect, when $\delta = |\delta_a - \delta_0|$ reaches the theoretic limit of 90°,

the maximum active power deliverable is achieved. As it was mentioned before, there is no need to wait for this difference to reach 90° to predict voltage instability. Thus, a critical angular difference $\delta_{critical}$ may be defined and in the case where $\delta = \delta_a - \delta_0 \geq \delta_{critical}$, then voltage instability is predicted. The ADI index may be calculated at different points of the power system being δ the general notation for the difference of the angles measured or estimated before and after the high voltage alternating current transmission **109**.

Thus, based on the above; one of the actions that may be performed once voltage instability is predicted ($|\delta_a - \delta_0| \geq \delta_{critical}$) is disconnecting the AC reactors (**113, 106**) in order to avoid larger reactive power consumption.

In some embodiments, a second verification is carried out in order to predict voltage instability and determine when the AC reactors (**113, 106**) may be disconnected. This verification is based on determining the voltage V of the bus where the AC compensations are connected; this verification is calculated in accordance with:

$$V \leq V_{sag1}$$

Wherein V_{sag1} is an adjustable parameter based on the specifications of the power system and if $V \leq V_{sag1}$ voltage instability is predicted.

As long as the AC reactors have been disconnected, the STATCOM **102** onshore may be performing in accordance with the grid code of the electrical grid **101**.

A further advantage offered by the present invention is that the difference in voltage angles may also be used to determine when the danger of instability has effectively disappeared. E.g. using the aforementioned index ADI for each of the buses in the system, it may be determined that the active power of the wind turbine may be increased again and/or that the DC chopper may be disconnected and/or that the AC reactors may be connected again.

Although only a number of particular embodiments and examples of the invention have been disclosed herein, it will be understood by those skilled in the art that other alternative embodiments and/or uses of the invention and obvious modifications and equivalents thereof are possible. Furthermore, the present invention covers all possible combinations of the particular embodiments described. Thus, the scope of the present invention should not be limited by particular embodiments, but should be determined only by a fair reading of the claims that follow.

The invention claimed is:

1. A method for predicting and avoiding a voltage instability in an electrical grid of an offshore wind park, the offshore wind park electrical grid being connected at a first end of a high voltage alternating current transmission and a main land electrical grid being connected at a second end of the high voltage alternating current transmission, and

the offshore wind park having a plurality of wind turbines connected to the wind park electrical grid, the method comprising:

determining a main land phase angle associated with the second end of the high voltage alternating current transmission,

measuring an individual wind turbine phase angle at one or more of the wind turbines,

determining a difference between each of the one or more measured individual wind turbine phase angles and the main land phase angle,

determining a threshold phase angle difference,

predicting voltage instability and performing an action to avoid the voltage instability when at least one of the differences between the measured individual wind tur-

bine phase angles and the main land phase angle exceeds the threshold phase angle difference; and

wherein determining the main land phase angle comprises measuring a phase angle associated with the first end of the high voltage alternating current transmission and calculating the main land phase angle at the second end based on a model of the high voltage alternating current transmission.

2. The method according to claim **1**, wherein the main land phase angle associated with the second end of the high voltage alternating current transmission is an angle of a voltage phasor associated with the second end of the high voltage alternating current transmission and the individual wind turbine phase angle at one of the wind turbines is an angle of a voltage phasor at the wind turbine.

3. The method according to claim **1**, wherein the individual wind turbine phase angle is measured at each of the wind turbines.

4. The method according to claim **2**, wherein when a difference between the main land phase angle and an individual wind turbine phase angle exceeds the threshold phase angle, active power generated by the corresponding wind turbine is reduced to avoid voltage instability.

5. The method according to claim **2**, wherein when a difference between at least one individual wind turbine phase angle and the main land phase angle exceeds the threshold phase angle, the active power generated by all the wind turbines of the wind park is reduced to avoid voltage instability.

6. The method according to claim **4**, wherein the reduction of the active power generated by the corresponding wind turbine involves the use of a DC chopper.

7. The method according to claim **1**, wherein one or more AC reactors are operatively provided for the first end and/or for the second end of the high voltage alternating current transmission, and wherein the method comprises disconnecting the one or more AC reactors when the difference between the at least one individual wind turbine phase angle and the main land phase angle exceeds the threshold phase angle to avoid voltage instability.

8. The method according to claim **1**, wherein the wind turbines have permanent magnet synchronous generators.

9. The method according to claim **1**, wherein each of the wind turbines is separately connected to a medium voltage line through a medium voltage transformer.

10. The method according to claim **1**, wherein the threshold phase angle difference is more than 60°.

11. The method according to claim **10**, wherein the threshold phase angle difference is 80°.

12. A method for avoiding voltage instability in an electrical grid of an offshore wind park, the offshore wind park electrical grid being connected at a first end of a high voltage alternating current transmission and a main land electrical grid being connected at a second end of the high voltage alternating current transmission, and

the wind park having a plurality of wind turbines, each of the wind turbines being connected to the wind park electrical grid, the method comprising:

determining a main land phase angle associated with the second end of the high voltage alternating current transmission,

measuring an individual wind turbine phase angle at one or more of the wind turbines,

determining a difference between each of the one or more measured individual wind turbine phase angles and the main land phase angle,

determining a threshold phase angle difference,

when at least one of the differences between the one or more measured individual wind turbine phase angles and the main land phase angle exceeds the threshold phase angle difference,

perform an action to avoid the voltage instability that 5
includes adjusting active and reactive power generated by one or more of the wind turbines, and wherein the adjusted active and reactive power to be generated by each of the one or more wind turbines is determined based on the corresponding difference between the 10
individual wind turbine phase angle and the main land phase angle.

13. The method according to claim **12**, wherein the main land phase angle associated with the second end of the high voltage alternating current transmission is an angle of a 15
voltage phasor associated with the second end of the high voltage alternating current transmission and the individual wind turbine phase angle at one of the wind turbines is an angle of a voltage phasor at the wind turbine.

* * * * *

20